



MERCER VALVE CO., INC.
"AUTO SEAT TECHNOLOGY"[®]

Repair Division
Ph: 800-503-8094
405-602-6744
Fax: 405-495-5771
REV 5 / 2/19/2020
OKCRP009-FM

CERTIFICATE OF COMPLIANCE

TEST ONLY

DATE	7/27/20
CUSTOMER	TULSA GAS
ADDRESS	4809 S. 101 ST E AVE
CITY, STATE, & ZIP CODE	TULSA, OK 74146
PURCHASE ORDER	BLUE / TRAILLE
SALES ORDER	R51741
JOB ORDER	
QTY	1
PART NUMBER	81-16151T09G11
INLET X OUTLET	1" X 1"
REPAIR SERIAL NUMBER	63644
ORIG. MFG. SERIAL NUMBER	611818
SERIES SAFETY RELIEF VALVE	81-E
SET PRESSURE	110 PSI
PSI TOLERANCE	+3%
TEST MEDIUM	AIR
TECHNICIAN SETTING VALVE	KH
DATE VALVE SET	7/23/20
TEST GAUGE USED	3000-75
GAUGE CALIBRATED BY DEAD WEIGHT TESTER ON	7/20/20
TESTED ON	STATION 26
CAPACITY	421 SCFM
CDTP	

LEAKAGE TIGHT AT 10% BELOW SET PRESSURE.

TINA HAWKINS
ASST. REPAIR MANAGER

THINK...MERCER FIRST™