

# Tulsa Gas Technologies, Inc.

4809 South 101st East Ave.  
Tulsa, OK 74146  
Phone 918-665-2641 Fax 918-665-2657

**Test Site:**

Tulsa Gas Technologies, Inc.  
4809 South 101st East Ave.  
Tulsa, OK 74146

**Work Order Number:**

SCG081419

**Dispenser Model Number:**

T7203-8CNG50W

**Dispenser Serial Number:**

19091269

**Eprom Number:**

1.04.13

# Calibration Report

**DATE:** December 10, 2019

**Test #**

**Test Date:** December 9, 2019

**Tested By:** Travis Heaps/C.R. Kendall

**Test Type** Acceptance

**CONTACT:** Jerry Kelley

**PHONE:** 918 665 2641

**Customer Name:**

Tulsa Gas Technologies  
4809 South 101st East Ave.  
Tulsa, OK. 74146

	SCALE	DISPENSER	PERCENT of ERROR
HOSE 1	MASS/GGE	GGE	
	12.64	12.630	0.08%
	13.11	13.090	0.15%
	12.82	12.820	0.00%
HOSE 2	12.24	12.370	-1.06%
	12.55	12.550	0.00%
	12.06	12.120	-0.50%

EXPECTABLE TOLERANCE IS + - 2% FOR EACH BATCH  
AND + - .8% BETWEEN BATCHES PER EACH HOSE

