



Tulsa Gas Technologies, Inc.

4809 S. 101st E. Ave., Tulsa, OK 74146

Phone: 918-665-2641 Fax: 918-665-2657

HYDRO TEST COMPLIANCE RECORD

Rubber 1" Hose

Date: 4-23-25

Customer Summit Utilities

Location Unit# 7985

Contact Name _____

Phone Number _____

Manufacture NA

Rated Pressure 350 PSI

Manufacture date NA

Lot# NA

Test Pressure 437.5 PSI for 30 sec. (125%)

Test ID Band number 6136884

Technician Printed Patrick McElhenny

Signature Patrick McElhenny



Tulsa Gas Technologies, Inc.

4809 S. 101st E. Ave., Tulsa, OK 74146

Phone: 918-665-2641 Fax: 918-665-2657

HYDRO TEST COMPLIANCE RECORD

Rubber 1" Hose

Date: 4-23-25

Customer Summit Utilities

Location Unit # 7485

Contact Name _____

Phone Number _____

Manufacture NA

Rated Pressure 350 PSI

Manufacture date NA

Lot# NA

Test Pressure 437.5 PSI for 30 sec. (125%)

Test ID Band number 6136888

Technician Printed Patrick McElhenny

Signature Patrick McElhenny