



# Tulsa Gas Technologies, Inc.

4809 S. 101st E. Ave., Tulsa, OK 74146

Phone: 918-665-2641 Fax: 918-665-2657

## HYDRO TEST COMPLIANCE RECORD

Date: 4-23-25

Customer Summit Utilities

Location unit # 7490

Contact Name \_\_\_\_\_

Phone Number \_\_\_\_\_

Manufacture \_\_\_\_\_

Rated Pressure 450 PSI

Manufacture date NA

Lot# NA

Test Pressure 565 PSI for 30 sec. (125%)

Test ID Band number 6136880

Technician Printed Patrick McElhenny

Signature Patrick McElhenny

Stainless Steel  
Braided - 1/2"

TGT S/N-19121278