

Summit Utilities AR  
 Unit #7490


Recvd 3/31/25

**CERTIFICATE OF COMPLIANCE**

**TEST ONLY**

DATE	3/28/25
CUSTOMER	TULSA GAS
ADDRESS	4809 S. 101 <sup>ST</sup> E AVE
CITY, STATE, & ZIP CODE	TULSA, OK 74146
PURCHASE ORDER	SUMM-RECERT
SALES ORDER	R61998
JOB ORDER	
QTY	1
PART NUMBER	91-16E51V10I1
INLET X OUTLET	1" X 1"
REPAIR SERIAL NUMBER	83708
ORIG. MFG. SERIAL NUMBER	1558756
SERIES SAFETY RELIEF VALVE	91-E
SET PRESSURE	250 PSI
PSI TOLERANCE	+3%
TEST MEDIUM	AIR
TECHNICIAN SETTING VALVE	JW
DATE VALVE SET	3/26/25
TEST GAUGE USED	3000-75
GAUGE CALIBRATED BY DEAD WEIGHT TESTER ON	3/10/25
TESTED ON	STATION 26
CAPACITY	921 SCFM
CDTP	

LEAKAGE TIGHT AT 10% BELOW SET PRESSURE.

  
**TINA HAWKINS**  
 REPAIR MANAGER