



Tulsa Gas Technologies, Inc.

4809 S. 101st E. Ave., Tulsa, OK 74146

Phone: 918-665-2641 Fax: 918-665-2657

HYDRO TEST COMPLIANCE RECORD

Date: 12-6-24

Customer Summit

Location NA

Contact Name NA

Phone Number NA

Manufacture Continental

Rated Pressure 200 PSI

Manufacture date NA

Lot#

Test Pressure 400 PSI for 30 sec. (125%)

Test ID Band number 6136574

Technician Printed Patrick McElheney

Signature Patrick McElheney

Summit Utilities OK

Unit # 7479

Brisson Parker- 580-512-3405