

HYDROSTATIC WATER JACKET TEST RETEST DATA SHEET

D.O.T. Regualification Identification Number (RIN): P746 and/or Transport Canada (TC) Registration Number: _____

Date: 01/02/2025

#	Cylinder Owner	Cylinder Serial Number	MFG ID	MFG Date	Gas Service	Physical Size (") (dia. x length)	Specification & Service Pressure	Actual Test Pressure	EXPANSION READINGS (cc's)				Visual Insp.		Disposition Code (*)	Retest Operator	
									Total	Permanent	Elastic	% Permanent	R/E	Pass			Fail
1	Summit Utilities	TS1-00347	Kaylor	12/82	NG	29.5/44.5	DOT 3AA3600	6000 psi	208.0	5.9	202.1	2.83			✓	A	BD
Notes:																	
2	Summit Utilities	K1748787Y	Norris	2/90	NG	24.5/44.5	DOT 3AA3600	6000 psi	184.3	2.3	182	1.24			✓	A	BD
Notes:																	
3	Summit Utilities	1071012Y	Norris	4/92	NG	29.5/44.5	DOT 3AA3600	6000 psi	200.3	5.7	194.6	2.84			✓	A	BD
Notes:																	
4	Summit Utilities	881618Y	Norris	2/91	NG	24.5/44.5	DOT 3AA3600	6000 psi	194.1	3.1	191	1.59			✓	A	BD
Notes:																	
5	Summit Utilities	TS1-002888	Taylor	12/82	NG	29.5/44.5	DOT 3AA3600	6000 psi	196.9	6.8	190.1	3.45			✓	A	BD
Notes:																	
6	Summit Utilities	1071010Y	Norris	4/92	NG	29.5/44.5	DOT 3AA3600	6000 psi	208.9	1.4	207.5	0.67			✓	A	BD
Notes:																	
7	Summit Utilities	1071024Y	Norris	4/92	NG	29.5/44.5	DOT 3AA3600	6000 psi	189.1	3.3	185.8	1.74			✓	A	BD
Notes:																	
8	Summit Utilities	1071016Y	Norris	4/92	NG	29.5/44.5	DOT 3AA3600	6000 psi	203.7	0.6	203.1	0.29			✓	A	BD
Notes:																	
9	Summit Utilities	881607Y	Norris	2/92	NG	24.5/44.5	DOT 3AA3600	6000 psi	202.8	1.7	201.1	0.83			✓	A	BD
Notes:																	
10	Summit Utilities	1142511Y	Norris	4/91	NG	24.5/44.5	DOT 3AA3600	6000 psi	188.1	1.9	186.2	1.01			✓	A	BD
Notes:																	
11	Summit Utilities	TS1-074456	Taylor	2/83	NG	24.5/44.5	DOT 3AA3600	6000 psi	201.8	2.8	199	1.38			✓	A	BD
Notes:																	
12	Summit Utilities	TS1-02956	Taylor	2/82	NG	29.5/44.5	DOT 3AA3600	6000 psi	196.7	2.7	194	1.37			✓	A	BD
Notes:																	

(*) Disposition Codes:

- A - Return to Service
- B - Hold for Retest
- C - Rejected
- D - Condemned
- E - Other (specify in notes)

I hereby certify that all of the above test were made under my supervision and in accordance with DOT and/or TC regulations.

(Facility Manager)

HYDROSTATIC WATER JACKET TEST RETEST DATA SHEET

D.O.T. Regualification Identification Number (RIN): A746 and/or Transport Canada (TC) Registration Number: _____

Date: 01/02/2025

#	Cylinder Owner	Cylinder Serial Number	MFG ID	MFG Date	Gas Service	Physical Size (") (dia. x length)	Specification & Service Pressure	Actual Test Pressure	EXPANSION READINGS (cc's)				Visual Insp.		Disposition Code (*)	Retest Operator	
									Total	Permanent	Elastic	% Permanent	Pass	Fail			
1	Summit Utilities	107102SV	Norris	4/6/2	NG	24.5/44.5	DOT3AA3600	6000 psi	220.7	10.8	24.4	4.84			✓	A	BD
Notes:																	
2	Summit Utilities	TS1-003030	Taylor	12/82	NG	24.5/44.5	DOT3AA3600	6000 psi	202.8	2.3	20.5	1.13			✓	A	BD
Notes:																	
3	Summit Utilities	K114252	Norris	3/6/2	NG	24.5/44.5	DOT3AA3600	6000 psi	200.7	5.7	14.5	2.84			✓	A	BD
Notes:																	
4																	
Notes:																	
5																	
Notes:																	
6																	
Notes:																	
7																	
Notes:																	
8																	
Notes:																	
9																	
Notes:																	
10																	
Notes:																	
11																	
Notes:																	
12																	
Notes:																	

I hereby certify that all of the above test were made under my supervision and in accordance with DOT and/or TC regulations.

(Facility Manager)

(*) Disposition Codes:

- A - Return to Service
- B - Hold for Retest
- C - Rejected
- D - Condemned
- E - Other (specify in notes)