



Tulsa Gas Technologies, Inc.

4809 S. 101st E. Ave., Tulsa, OK 74146

Phone: 918-665-2641 Fax: 918-665-2657

HYDRO TEST COMPLIANCE RECORD

Date: 1-17-25

Customer Summit Utilities-AR-unit # 7496 TGT SN-20011283

Location 3013 Ole Feed House RD Jackson, AR 72404

Contact Name Ron Wood

Phone Number 870-219-8765

Manufacture NA

Rated Pressure 400 PSI - SS Braided Hose

Manufacture date NA 30 ft 1-in dia

Lot# NA

Test Pressure 575 PSI for 30 sec. (125%)

Test ID Band number 6136555

Technician Printed Patrick McElheney

Signature Patrick mcelheney