

HYDROSTATIC WATER JACKET TEST RETEST DATA SHEET

D.O.T. Recertification Identification Number (RIN): 9746

and/or Transport Canada (TC) Registration Number: _____

Date: 12/29/2024

Date: 12/29/2024									EXPANSION READINGS (cc's)					Visual Insp.			Disposition Code (*)	Retest Operator
#	Cylinder Owner	Cylinder Serial Number	MFG ID	MFG Date	Gas Service	Physical Size (") (dia. x length)	Specification & Service Pressure	Actual Test Pressure	Total	Permanent	Elastic	% Permanent	REE	Pass	Fail			
Calibrated Cylinder: Be sure to verify the system accuracy with the calibrated cylinder prior to each day of testing. Use the back of this form to properly record the verification procedure																		
1	Summit Utilities	T51-003055	Taylor	12/82	NG	29.5/44.5	DOT 3AA 3600	6000psi	189.3	2.4	181.9	1.26		✓		A	BD	
Notes:																		
2	Summit Utilities	T51-002430	Taylor	12/82	NG	29.5/44.5	DOT 3AA 3600	6000psi	198.1	3.1	195	1.56		✓		A	BD	
Notes:																		
3	Summit Utilities	T51-003058	Taylor	12/82	NG	29.5/44.5	DOT 3AA 3600	6000psi	192.1	0.4	191.7	0.20		✓		A	BD	
Notes:																		
4	Summit Utilities	T51-002476	Taylor	12/82	NG	29.5/44.5	DOT 3AA 3600	6000psi	195.7	1.7	194	0.86		✓		A	BD	
Notes:																		
5	Summit Utilities	T51-002985	Taylor	12/82	NG	29.5/44.5	DOT 3AA 3600	6000psi	187.7	5.2	182.5	2.77		✓		A	BD	
Notes:																		
6	Summit Utilities	T51-029493	Taylor	12/82	NG	29.5/44.5	DOT 3AA 3600	6000psi	192.3	1.9	190.4	0.98		✓		A	BD	
Notes:																		
7	Summit Utilities	T51-029431	Taylor	12/83	NG	29.5/44.5	DOT 3AA 3600	6000psi	189.1	2.5	186.6	1.32		✓		A	BD	
Notes:																		
8	Summit Utilities	T51-002867	Taylor	12/82	NG	29.5/44.5	DOT 3AA 3600	6000psi	198.7	6.4	191.8	3.47		✓		A	BD	
Notes:																		
9	Summit Utilities	T51-029477	Taylor	12/83	NG	29.5/44.5	DOT 3AA 3600	6000psi	196.1	2.8	193.3	1.42		✓		A	BD	
Notes:																		
10	Summit Utilities	T51-002402	Taylor	12/82	NG	29.5/44.5	DOT 3AA 3600	6000psi	201.1	1.8	199.3	0.89		✓		A	BD	
Notes:																		
11	Summit Utilities	T51-024518	Taylor	2/83	NG	29.5/44.5	DOT 3AA 3600	6000psi	198.7	0.9	197.8	0.45		✓		A	BD	
Notes:																		
12	Summit Utilities	T51-024502	Taylor	2/83	NG	29.5/44.5	DOT 3AA 3600	6000psi	189.1	4.8	184.3	2.53		✓		A	BD	
Notes:																		

I hereby certify that all of the above test were made under my supervision and in accordance with DOT and/or TC regulations.

[Signature] (Facility Manager)

(*) Disposition Codes:

- A - Return to Service
- B - Hold for Retest
- C - Rejected
- D - Condemned
- E - Other (specify in notes)

This form meets the requirements for recording of cylinder re-qualification under CFR Title 49 §180.215

Reorder no. 393-001 Revision 2021-06
hydro-test.com

HYDROSTATIC WATER JACKET TEST RETEST DATA SHEET

D.O.T. Regualification Identification Number (RIN): A746

and/or Transport Canada (TC) Registration Number: _____

Date: 2/29/2024

#	Cylinder Owner	Cylinder Serial Number	MFG ID	MFG Date	Gas Service	Physical Size (") (dia. x length)	Specification & Service Pressure	Actual Test Pressure	EXPANSION READINGS (cc's)					Visual Insp.		Disposition Code (*)	Retest Operator
									Total	Permanent	Elastic	% Permanent	REE	Pass	Fail		
Calibrated Cylinder: Be sure to verify the system accuracy with the calibrated cylinder prior to each day of testing. Use the back of this form to properly record the verification procedure																	
1	Summit Utilities	TS1002000	Taylor	12/82	NG	24.5/44.5	DOT 3AA 3600	6000psi	187.1	1.1	186	0.58		✓		A	BD
Notes:																	
2	Summit Utilities	TS1-029411	Taylor	12/83	NG	24.5/44.5	DOT 3AA 3600	6000psi	185.1	2.7	182.4	1.45		✓		A	BD
Notes:																	
3	Summit Utilities	TS10029409	Taylor	12/82	NG	24.5/44.5	DOT 3AA 3600	6000psi	184.3	1.6	182.7	0.86		✓		A	BD
Notes:																	
4																	
Notes:																	
5																	
Notes:																	
6																	
Notes:																	
7																	
Notes:																	
8																	
Notes:																	
9																	
Notes:																	
10																	
Notes:																	
11																	
Notes:																	
12																	
Notes:																	

I hereby certify that all of the above test were made under my supervision and in accordance with DOT and/or TC regulations.

(*) Disposition Codes:

- A - Return to Service
- B - Hold for Retest
- C - Rejected
- D - Condemned
- E - Other (specify in notes)

This form meets the requirements for recording of cylinder re-qualification under CFR Title 49 §180.215

Reorder no. 393-001 Revision 2021-06
hydro-test.com

(Facility Manager)