



MERCER VALVE CO., INC.®
"AUTO SEAT TECHNOLOGY"®

Repair Division
Ph: 800-503-8094
405-602-6744
Fax: 405-495-5771
REV 5 / 2/19/2020
OKCRP009-FM

TGT S/N-20011285
PD-SUA061125
Summit Util. Inc. XR-Unit 7510

CERTIFICATE OF COMPLIANCE

TEST ONLY

DATE	7/7/25
CUSTOMER	TULSA GAS
ADDRESS	4809 S. 101 ST E AVE
CITY, STATE, & ZIP CODE	TULSA, OK 74146
PURCHASE ORDER	SAU061125
SALES ORDER	R63080
JOB ORDER	
QTY	1
PART NUMBER	91-16E51V1011
INLET X OUTLET	1" X 1"
REPAIR SERIAL NUMBER	84901
ORIG. MFG. SERIAL NUMBER	1558749
SERIES SAFETY RELIEF VALVE	91-E
SET PRESSURE	250 PSI
PSI TOLERANCE	+3%
TEST MEDIUM	AIR
TECHNICIAN SETTING VALVE	JW
DATE VALVE SET	7/3/25
TEST GAUGE USED	3000-75
GAUGE CALIBRATED BY DEAD WEIGHT TESTER ON	6/9/25
TESTED ON	STATION 26
CAPACITY	921 SCFM
CDTP	

LEAKAGE TIGHT AT 10% BELOW SET PRESSURE.


TINA HAWKINS
REPAIR MANAGER

THINK...MERCER FIRST™