

HOSE 1

Prover Starting Mass	0.0000					
Prover 1st Batch	10.7300					
Dispenser 1st Batch	10.786	-0.52 %				
Prover 2nd Batch	21.6600					
Dispenser 2nd Batch	10.978	-0.44 %				
Prover 3rd Batch	32.5900					
Dispenser 3rd Batch	10.874	0.51 %				
Prover 4th Batch	0.000					
Dispenser 4th Batch	0.000	100.00 %				
STARTING PROVER READING						
Lb/GGE	0.0000	SCALE	SCALE/GGE	GALLONS	PERCENT of ERROR	NEW GGE FACTOR
1	10.7300	10.7300	10.730	10.786	-0.52	1.00
	21.6600	10.9300	10.930	10.978	-0.44	
	32.5900	10.9300	10.930	10.874	0.51	
						-0.15%

HOSE 2

Prover Starting Mass	0.0000					
Prover 1st Batch	1.0000					
Dispenser 1st Batch	1.000	0.00 %				
Prover 2nd Batch	2.0000					
Dispenser 2nd Batch	1.000	0.00 %				
Prover 3rd Batch	3.0000					
Dispenser 3rd Batch	1.000	0.00 %				
Prover 4th Batch						
Dispenser 4th Batch		100.00 %				
STARTING PROVER READING						
Lb/GGE	0.0000	SCALE	SCALE/GGE	GALLONS	PERCENT of ERROR	NEW GGE FACTOR
1	1.0000	1.0000	1.000	1.000	0.00	1.00
	2.0000	1.0000	1.000	1.000	0.00	
	3.0000	1.0000	1.000	1.000	0.00	
						0.00%

Tulsa Gas Technologies, Inc.

Calibration Report

4809 South 101st East Ave.
Tulsa, OK 74146
Phone 918-665-2641 Fax 918-665-2657

DATE: August 13, 2020
Test # 1
Test Date: August 3, 2020
Tested By: Garrett Bias/C.R. Kendall
Test Type Acceptance

Test Site:
Tulsa Gas Technologies, Inc.
4809 South 101st East Ave.
Tulsa, OK 74146

CONTACT: Jerry Kelley
PHONE: 918 665 2641

Work Order Number:
TRIL012420

Customer Name:
Tulsa Gas Technologies
4809 South 101st East Ave.
Tulsa, OK. 74146

Dispenser Model Number:
T-7214-12CNG50

Dispenser Serial Number:
20041290

Eprom Number:
1.02.30TPF

	SCALE	DISPENSER	PERCENT of ERROR
HOSE 1	MASS/GGE	GGE	
	10.73	10.786	-0.52%
	10.93	10.978	-0.44%
	10.93	10.874	0.51%
HOSE 2	1.00	1.000	0.00%
	1.00	1.000	0.00%
	1.00	1.000	0.00%

EXPECTABLE TOLERANCE IS + - 2% FOR EACH BATCH
AND + - .8% BETWEEN BATCHES PER EACH HOSE