

HOSE 1

Prover Starting Mass	0.0000					
Prover 1st Batch	10.8000					
Dispenser 1st Batch	10.698	0.94 %				
Prover 2nd Batch	21.4100					
Dispenser 2nd Batch	10.596	0.13 %				
Prover 3rd Batch	32.0000					
Dispenser 3rd Batch	10.560	0.28 %				
Prover 4th Batch	0.000					
Dispenser 4th Batch	0.000	100.00 %				
STARTING PROVER READING						
Lb/GGE	0.0000	SCALE	SCALE/GGE	GALLONS	PERCENT of ERROR	NEW GGE FACTOR
1	10.8000	10.8000	10.800	10.698	0.94	1.00
	21.4100	10.6100	10.610	10.596	0.13	
	32.0000	10.5900	10.590	10.560	0.28	
						0.45%

HOSE 2

Prover Starting Mass	0.0000					
Prover 1st Batch	1.0000					
Dispenser 1st Batch	1.000	0.00 %				
Prover 2nd Batch	2.0000					
Dispenser 2nd Batch	1.000	0.00 %				
Prover 3rd Batch	3.0000					
Dispenser 3rd Batch	1.000	0.00 %				
Prover 4th Batch						
Dispenser 4th Batch		100.00 %				
STARTING PROVER READING						
Lb/GGE	0.0000	SCALE	SCALE/GGE	GALLONS	PERCENT of ERROR	NEW GGE FACTOR
1	1.0000	1.0000	1.000	1.000	0.00	1.00
	2.0000	1.0000	1.000	1.000	0.00	
	3.0000	1.0000	1.000	1.000	0.00	
						0.00%

Tulsa Gas Technologies, Inc.

4809 South 101st East Ave.
Tulsa, OK 74146
Phone 918-665-2641 Fax 918-665-2657

Test Site:

Tulsa Gas Technologies, Inc.
4809 South 101st East Ave.
Tulsa, OK 74146

Work Order Number:

TRIL012420

Dispenser Model Number:

T-7214-12CNG50

Dispenser Serial Number:

20041292

Eprom Number:

1.02.30TPF

Calibration Report

DATE: August 13, 2020

Test # 1

Test Date: August 3, 2020

Tested By: Garrett Bias/C.R. Kendall

Test Type Acceptance

CONTACT: Jerry Kelley

PHONE: 918 665 2641

Customer Name:

Tulsa Gas Technologies
4809 South 101st East Ave.
Tulsa, OK. 74146

SCALE DISPENSER PERCENT of ERROR			
HOSE 1	MASS/GGE	GGE	
	10.80	10.698	0.94%
	10.61	10.596	0.13%
	10.59	10.560	0.28%
HOSE 2	1.00	1.000	0.00%
	1.00	1.000	0.00%
	1.00	1.000	0.00%

EXPECTABLE TOLERANCE IS + - 2% FOR EACH BATCH
AND + - .8% BETWEEN BATCHES PER EACH HOSE