

Cylinder Requalification Report

DOT/TC Registration # CO19

Fullerton Hydro Test Inc

25318 S. Hwy 88

Inola, OK 74036

Code Has Three Letters: 1st Letter: Visual Test, 2nd Letter: % Perm Exp Test, 3rd Letter: REE Test
Letter Code: P=Passed, F=Failed, N=Not Applicable, A=Aborted **Example:** PPP=Passed Visual, Passed % Prm, Passed REE

Operator Signature: _____

Date Signed: _____

Supervisor Signature: _____

Date Signed: 9-25-20

I hereby certify that all the following tests were made under my supervision and in accordance with DOT/CTC regulations.

#	Test Date Test Time	Operator	Serial Number Cyl Owner	Size Service	Cyl MFG. MFG. Date	REE Source	Rating Unit	Specified Actual	Test Time	Total Elastic	Perm Percen	+* VE	VE Date Ref Ring	Disposition Remark
1	9/10/2020 9:40	Dustin Phillips	TW-H-935744 TULSA GAS	9.25x51 Spec Gas	TW 6/92	229 C5	3AA-3600 PSI	6000 6009	30	198.5 196.5	2.0 1.0			PPP
2	9/10/2020 9:43	Dustin Phillips	TW-H-935653 TULSA GAS	9.25x51 Spec Gas	TW 6/92	229 C5	3AA-3600 PSI	6000 6000	30	199.1 198.1	1.0 0.5			PPP
3	9/10/2020 9:47	Dustin Phillips	TW-H-928431 TULSA GAS	9.25x51 Spec Gas	TW 5/92	229 C5	3AA-3600 PSI	6000 6002	30	203.6 199.6	4.0 1.9			PPP
4	9/10/2020 9:53	Dustin Phillips	TW-H-928406 TULSA GAS	9.25x51 Spec Gas	TW 5/92	229 C5	3AA-3600 PSI	6000 6018	30	199.1 196.1	3.0 1.5			PPP
5	9/10/2020 9:58	Dustin Phillips	TW-H-928437 TULSA GAS	9.25x51 Spec Gas	TW 5/92	229 C5	3AA-3600 PSI	6000 6010	30	200.0 197.0	3.0 1.5			PPP
6	9/10/2020 10:05	Dustin Phillips	1473527Y TULSA GAS	9.25x51 Spec Gas	CL 10/94	230 C5	3AA-3600 PSI	6000 5996	30	201.7 0.0	0.0 0.0			PAA 88
7	9/10/2020 10:10	Dustin Phillips	1473527Y TULSA GAS	9.25x51 Spec Gas	CL 10/94	230 C5	3AA-3600 PSI	6100 6114	30	205.3 203.3	2.0 0.9			PPP Retest at +100/1
8	9/10/2020 10:16	Dustin Phillips	1473248Y TULSA GAS	9.25x51 Spec Gas	CL 10/94	230 C5	3AA-3600 PSI	6000 6017	30	201.3 200.3	1.0 0.5			PPP
9	9/10/2020 10:23	Dustin Phillips	1473255Y TULSA GAS	9.25x51 Spec Gas	CL 10/94	230 C5	3AA-3600 PSI	6000 6016	30	199.3 196.3	3.0 1.5			PPP
10	9/10/2020 10:30	Dustin Phillips	1473254Y TULSA GAS	9.25x51 Spec Gas	CL 10/94	230 C5	3AA-3600 PSI	6000 6016	30	202.6 199.5	3.1 1.5			PPP
11	9/10/2020 10:39	Dustin Phillips	1473246Y TULSA GAS	9.25x51 Spec Gas	CL 10/94	230 C5	3AA-3600 PSI	6000 6003	30	204.2 203.2	1.0 0.4			PPP
12	9/10/2020 10:43	Dustin Phillips	TW-H-928417 TULSA GAS	9.25x51 Spec Gas	TW 5/92	229 C5	3AA-3600 PSI	6000 6020	30	204.6 201.6	3.0 1.4			PPP
13	9/10/2020 10:50	Dustin Phillips	TW-H-928410 TULSA GAS	9.25x51 Spec Gas	TW 5/92	229 C5	3AA-3600 PSI	6000 6018	30	203.9 201.9	2.0 0.9			PPP
14	9/10/2020 10:56	Dustin Phillips	1473251Y TULSA GAS	9.25x51 Spec Gas	CL 10/94	230 C5	3AA-3600 PSI	6000 6017	30	202.3 201.3	1.0 0.4			PPP
1	9/11/2020 9:04	Dustin Phillips	1473253Y TULSA GAS	9.25x51 Spec Gas	CL 10/94	230 C5	3AA-3600 PSI	6000 6017	30	199.3 199.3	0.0 0.0			PPP

#	Test Date Test Time	Operator	Serial Number Cyl Owner	Size Service	Cyl MFG. MFG. Date	REE Source	Rating Unit	Specified Actual	Test Time	Total Elastic	Perm Percen	+* VE	VE Date Ref Ring	Disposition Remark
2	9/11/2020 9:08	Dustin Phillips	TW-H-935773 TULSA GAS	9.25x51 Spec Gas	TW 6/92	230 C5	3AA-3600 PSI	6000 6013	30	205.6 203.6	2.0 0.9			PPP
3	9/11/2020 9:20	Dustin Phillips	1473245Y TULSA GAS	9.25x51 Spec Gas	CL 10/94	230 C5	3AA-3600 PSI	6000 6019	30	203.6 200.6	3.0 1.4			PPP
4	9/11/2020 9:29	Dustin Phillips	1473249Y TULSA GAS	9.25x51 Spec Gas	CL 10/94	230 C5	3AA-3600 PSI	6000 6015	30	203.0 201.0	2.0 0.9			PPP
5	9/11/2020 9:36	Dustin Phillips	TW-H-928508 TULSA GAS	9.25x51 Spec Gas	TW 5/92	229 C5	3AA-3600 PSI	6000 6015	30	198.6 195.6	3.0 1.5			PPP
6	9/11/2020 9:43	Dustin Phillips	1473247Y TULSA GAS	9.25x51 Spec Gas	CL 10/94	230 C5	3AA-3600 PSI	6000 6017	30	202.6 200.6	2.0 0.9			PPP
7	9/11/2020 9:47	Dustin Phillips	TW-H-928415 TULSA GAS	9.25x51 Spec Gas	TW 5/92	229 C5	3AA-3600 PSI	6000 6016	30	202.0 200.0	2.0 0.9			PPP
8	9/11/2020 9:53	Dustin Phillips	1473239Y TULSA GAS	9.25x51 Spec Gas	CL 10/94	230 C5	3AA-3600 PSI	6000 6015	30	202.2 200.1	2.1 1.0			PPP
9	9/11/2020 9:57	Dustin Phillips	TW-H-93564 TULSA GAS	9.25x51 Spec Gas	TW 6/92	229 C5	3AA-3600 PSI	6000 6009	30	201.7 199.7	2.0 0.9			PPP
10	9/11/2020 10:03	Dustin Phillips	TW-H-928430 TULSA GAS	9.25x51 Spec Gas	TW 5/92	229 C5	3AA-3600 PSI	6000 6015	30	200.8 198.8	2.0 1.0			PPP
11	9/11/2020 10:11	Dustin Phillips	TW-H-935763 TULSA GAS	9.25x51 Spec Gas	TW 5/92	229 C5	3AA-3600 PSI	6000 6001	30	198.3 197.3	1.0 0.5			PPP
12	9/11/2020 10:15	Dustin Phillips	TW-H-935756 TULSA GAS	9.25x51 Spec Gas	TW 6/92	229 C5	3AA-3600 PSI	6000 6016	30	198.3 196.3	2.0 1.0			PPP
13	9/11/2020 10:20	Dustin Phillips	TW-H-928475 TULSA GAS	9.25x51 Spec Gas	TW 5/92	229 C5	3AA-3600 PSI	6000 6016	30	203.8 201.8	2.0 0.9			PPP
14	9/11/2020 10:27	Dustin Phillips	TW-H-928391 TULSA GAS	9.25x51 Spec Gas	TW 5/92	229 C5	3AA-3600 PSI	6000 6024	30	206.0 204.0	2.0 0.9			PPP
15	9/11/2020 10:32	Dustin Phillips	TW-H-935691 TULSA GAS	9.25x51 Spec Gas	TW 6/92	229 C5	3AA-3600 PSI	6000 6007	30	202.0 201.0	1.0 0.5			PPP
16	9/11/2020 10:36	Dustin Phillips	1473240Y TULSA GAS	9.25x51 Spec Gas	CL 10/94	230 C5	3AA-3600 PSI	6000 6008	30	201.1 200.1	1.0 0.5			PPP
17	9/11/2020 10:41	Dustin Phillips	1473252Y TULSA GAS	9.25x51 Spec Gas	CL 10/94	230 C5	3AA-3600 PSI	6000 6011	30	200.0 199.0	1.0 0.5			PPP

Cylinder Result Summary

DOT/TC Registration #

Fullerton Hydro Test Inc

25318 S. Hwy 88

Inola, OK 74036

*Revised List 9/25/20
Jm*

Cyl Owner	Number of Passed Results	Number of Condemned Results	Number of Eddy Current Results
TULSA GAS	30	0	0