



Tulsa Gas Technologies, Inc.

4809 S. 101st E. Ave., Tulsa, OK 74146

Phone: 918-665-2641 Fax: 918-665-2657

HYDRO TEST COMPLIANCE RECORD

Date: 4-28-25

TGT S/N-14101022

Customer New Mexico Gas

1" Hose by 24"

Location # 10115 piece 1 of 2

Contact Name _____

Phone Number _____

Manufacture Dayco

Rated Pressure 350 PSI

Manufacture date 04/02

Lot# E-7466

Test Pressure 437.5 PSI for 30 sec. (125%)

Test ID Band number 6136882

Technician Printed Patrick McElheney

Signature Patrick McElheney



Tulsa Gas Technologies, Inc.

4809 S. 101st E. Ave., Tulsa, OK 74146

Phone: 918-665-2641 Fax: 918-665-2657

HYDRO TEST COMPLIANCE RECORD

Date: 4-28-25

TGT S/N-14101022
1" Hose by 50-ft

Customer New Mexico Gas

Location #10115 piece 2 of 2

Contact Name _____

Phone Number _____

Manufacture Dayco

Rated Pressure 350 PSI

Manufacture date 04/02

Lot# E-7466

Test Pressure 437.5 PSI for 30 sec. (125%)

Test ID Band number 6136886

Technician Printed Patrick McElheney

Signature Patrick McElheney