

PO-BHE061925

Repair Division
Ph: 800-503-8094
405-602-6744
Fax: 405-495-5771
REV 5 / 2/19/2020

Black Hills Energy
Unit # 10052863
TGT S/N-15051071


DM 9/11/25

CERTIFICATE OF COMPLIANCE

TEST ONLY

DATE	9/9/25
CUSTOMER	TULSA GAS
ADDRESS	4809 S. 101 ST E AVE
CITY, STATE, & ZIP CODE	TULSA, OK 74146
PURCHASE ORDER	BHE061925
SALES ORDER	R63602
JOB ORDER	
QTY	1
PART NUMBER	91-16E51V09I1
INLET X OUTLET	1" X 1"
REPAIR SERIAL NUMBER	85570
ORIG. MFG. SERIAL NUMBER	1171043
SERIES SAFETY RELIEF VALVE	91-E
SET PRESSURE	150 PSI
PSI TOLERANCE	+3%
TEST MEDIUM	AIR
TECHNICIAN SETTING VALVE	JW
DATE VALVE SET	9/4/25
TEST GAUGE USED	3000-75
GAUGE CALIBRATED BY DEAD WEIGHT TESTER ON	6/9/25
TESTED ON	STATION 26
CAPACITY	571 SCFM
CDTP	

LEAKAGE TIGHT AT 10% BELOW SET PRESSURE.


DEAN YORK
ASST. OPERATIONS SUPERVISOR

THINK...MERCER FIRST™