

Cylinder Requalification Report

DOT/TC Registration #

Galiso, Inc

22 Ponderosa Ct.

Montrose, CO 81401

Code Has Three Letters: 1st Letter: Visual Test, 2nd Letter: % Perm Exp Test, 3rd Letter: REE Test

Letter Code: P=Passed, F=Failed, N=Not Applicable, A=Aborted **Example:** PPP-Passed Visual, Passed % Prm, Passed REE

PCAL, FCAL used for passed, failed calibration verification test, respectively; **PASS/FAIL** used proof tests-no REE, no % perm criteria

Operator Signature:

Date Signed:

Supervisor Signature:

Date Signed:

I hereby certify that all the following tests were made under my supervision and in accordance with DOT/CTC regulations.

Trailer No.

#	Test Date Test Time	Operator	Serial Number Cyl Owner	Size Service	Cyl MFG. MFG. Date	REE Source	Rating Unit	Specified Actual	Test Time	Total Elastic	Perm Percen	+* VE	VE Date Ref Ring	Disposition Remark
24	4/16/2025 13:46	DUSTIN PHILLIPS	HP537824 TULSA GAS	9.25x55 METHANE	M9601 08/16	278 C5	3AA-2400 PSI	4000 4016	30	248.0 246.0	2.0 0.8			PPP 510
25	4/16/2025 13:59	DUSTIN PHILLIPS	HP537826 TULSA GAS	9.25x55 METHANE	M9601 08/16	278 C5	3AA-2400 PSI	4000 4017	30	248.4 248.4	0.0 0.0			PPP 510
26	4/16/2025 14:05	DUSTIN PHILLIPS	HP537822 TULSA GAS	9.25x55 METHANE	M9601 08/16	278 C5	3AA-2400 PSI	4000 4017	30	253.4 251.4	2.0 0.7			PPP 510
27	4/16/2025 14:11	DUSTIN PHILLIPS	HP537823 TULSA GAS	9.25x55 METHANE	M9601 08/16	278 C5	3AA-2400 PSI	4000 4009	30	238.3 237.3	1.0 0.4			PPP 513
28	4/16/2025 14:17	DUSTIN PHILLIPS	HP559189 TULSA GAS	9.25x55 METHANE	M9601 09/17	278 C5	3AA-2400 PSI	4000 4013	30	251.3 249.3	2.0 0.8			PPP 513
29	4/16/2025 14:24	DUSTIN PHILLIPS	HP559206 TULSA GAS	9.25x55 METHANE	M9601 09/17	278 C5	3AA-2400 PSI	4000 4006	30	252.3 250.3	2.0 0.7			PPP 513
30	4/16/2025 14:32	DUSTIN PHILLIPS	HP559203 TULSA GAS	9.25x55 METHANE	M9601 09/17	278 C5	3AA-2400 PSI	4000 4017	30	245.5 243.5	2.0 0.8			PPP 513
31	4/16/2025 14:39	DUSTIN PHILLIPS	HP537819 TULSA GAS	9.25x55 METHANE	M9601 08/16	278 C5	3AA-2400 PSI	4000 4018	30	238.1 236.1	2.0 0.8			PPP 513
32	4/16/2025 14:46	DUSTIN PHILLIPS	HP559196 TULSA GAS	9.25x55 METHANE	M9601 09/17	278 C5	3AA-2400 PSI	4000 4018	30	247.9 245.9	2.0 0.8			PPP 510
33	4/16/2025 14:51	DUSTIN PHILLIPS	HP537816 TULSA GAS	9.25x55 METHANE	M9601 08/16	278 C5	3AA-2400 PSI	4000 4007	30	248.3 246.3	2.0 0.8			PPP 510

New Mexico Gas Recertification, 2 Trailers, 5 Bottles Each
2400 PSI Bottles As of: 05/09/2025

Purchase Order #: NMG092024B

10 Bottles for Fullerton Hydrotesting

Fullerton Pallet No. : 43

Date Taken for Testing 4/4/2025

Date Certified 4/15/2025

Date Returned to TGT 5/2/2025

Bottle SN#

Trailer # 18510 S/N - 25031496

✓ HP537826 5

✓ HP537824 4

✓ HP537816 3

✓ HP537822 2

✓ HP559196 1

Trailer # 18513 S/N - 25031497

✓ HP559189 5

✓ HP559203 4

✓ HP559206 3

✓ HP537819 2

✓ HP537823 1

Trailer #

5

4

3

2

1

NOTE: ALL 15 BOTTLES ARE 2400 PSI

If you have any questions, please call Greg Miller at 918-624-2641