


TGT S/W-2503/496

NMGas Unit #18510

Print Date: 5/1/2025

	Total Valve Systems		1300 E Memphis St, Broken Arrow OK 74012, USA	
	Phone: 800-324-7035	Email: sales@totalvalve.com	Date:	04/9/2025
www.totalvalve.com		T/O Inspection and Checklist		TVS order #: 25-33894-1-100

Customer:	TULSA GAS TECHNOLOGIES	PO#:		Test No:	76410
PSV:	NO TAG	Location/SAP:		Unit:	
				Service Media:	Liquid
Service	Test Only		Reset		New Valve Assy
Valve	X				
Pilot Valve					

Valve Mfr:	SWAGelok	Size:	.5-.5	Model:	SS-R4M8F8
Serial No:	0001827603	Inlet:	MNPT	Capacity:	
Set Pressure:	65 psi	Outlet:	FNPT	CDTP:	
B.P.:	const:	var:		Temp:	
ASME Code:	NA/Other	Mfg Date:		Cap Assm:	Closed
Pilot valve model:		Pilot serial:		Soft Seat Mat:	
				Pilot set:	
				Pilot trim:	

Previous Repair Data	Company:	NEW VALVE	W/O#:	
	Set:		Capacity:	
			Date:	

As found test data	Set Pressure:		Pass/Fail:		Reclosed:		API 527 Results:	
	API 527 Test:		B.P. Test:		B.P. Pass/Fail/NT:		Tight:	
	Tested by:		Date:		Gauge ID:		Test Stand #:	

Visual Inspection of Main Valve Parts	Received Condition											Comments
	Good	Dirty	Plugged	Pitted	Cut	Corroded	Galled	Broken	Missing	Abnormal wear	Cleanliness(0-5)	
Spring												
Bonnet												
Inlet flange												
Outlet flange												
Disc												
Nozzle												
Nozzle ring												
Nozzle ring pin												
Body	X											
Spindle												
Cap Assembly	X											
Bellows												
Seals / Safety Wire	X											

Inspected by: _____ Date: _____

As left test data.	Set pressure:	65.1 psi	Reclose:	4.6 psi	Tight at:	58.5 psi	API 527 Results:	Pass
	Comp Screw:		CDTP:	65	BP Tested to:	30	Gauge ID:	363922
	Media:	Water	Tested By:	djones	Witness:		Date:	04/11/2025

Test Method	Pop:	X	Hydroset:		Other:	
Comments						

Final Inspection	T/O Stamp:	X	Sealed:	X	Tagged:	X	Paperwork:	X
Reviewed and approved by:	dplaster	DA240			Date:	04/12/2025		
Revised June, 2020 Approved by: M. Lybarger								