

Cylinder Requalification Report

DOT/TC Registration # C019

FULLERTON HYDRO TEST

25318 S HWY 88

INOLA, OK 74036

Charge Acct

PO-BHCO13125TSB

Om 8/14/25

Code Has Three Letters: 1st Letter: Visual Test, 2nd Letter: % Perm Exp Test, 3rd Letter: REE Test

Letter Code: P=Passed, F=Failed, N=Not Applicable, A=Aborted **Example:** PPP=Passed Visual, Passed % Perm, Passed REE

PCAL, FCAL used for passed, failed calibration verification test, respectively; **PASS/FAIL** used proof tests-no REE, no % perm criteria

Operator Signature:

Date Signed:

Supervisor Signature:

Date Signed:

I hereby certify that all the following tests were made under my supervision and in accordance with DOT/CTC regulations.

#	Test Date Test Time	Operator	Serial Number Cyl Owner	Size Service	Cyl MFG. MFG. Date	REE Source	Rating Unit	Specified Actual	Test Time	Total Elastic	Perm Percen	+* VE	VE Date Ref Ring	Disposition Remark
1	8/11/2025 8:33	DUSTIN PHILLIPS	CX-7337-HS TULSA GAS 2	9.25x51 CNG	CL 10/68	229 C5	3AA-3500 PSI	5833 5846	30	194.2 192.2	2.0 1.0			PPP
2	8/11/2025 8:39	DUSTIN PHILLIPS	CX-1462-HS TULSA GAS 2	9.25x51 CNG	CL 06/67	229 C5	3AA-3500 PSI	5833 5846	30	203.2 198.2	5.0 2.4			PPP
3	8/11/2025 8:53	DUSTIN PHILLIPS	KI 763452Y TULSA GAS 2	9.25x51 CNG	CL 02/96	230 C5	3AA-3600 PSI	6000 6008	30	211.4 208.4	3.0 1.4			PPP
4	8/11/2025 8:58	DUSTIN PHILLIPS	H-41017 TULSA GAS 2	9.25x51 CNG	CL 11-65	229 C5	3AA-3500 PSI	5833 5850	30	197.8 196.8	1.0 0.5			PPP
5	8/11/2025 9:07	DUSTIN PHILLIPS	N31515 TULSA GAS 2	9.25x51 CNG	CL 11/55	229 C5	3AA-3500 PSI	5833 5840	30	201.8 199.8	2.0 0.9			PPP
6	8/11/2025 9:15	DUSTIN PHILLIPS	KI 763468Y TULSA GAS 2	9.25x51 CNG	CL 02-90	230 C5	3AA-3600 PSI	6000 6010	30	210.3 208.3	2.0 0.9			PPP
7	8/11/2025 9:48	DUSTIN PHILLIPS	H-35561 TULSA GAS 2	9.25x51 CNG	CL 01/65	229 C5	3AA-3500 PSI	5833 5845	30	200.0 198.0	2.0 1.0			PPP
8	8/11/2025 10:27	DUSTIN PHILLIPS	CX-1240-HS TULSA GAS 2	9.25x51 CNG	CL 06/67	229 C5	3AA-3500 PSI	5833 5845	30	203.8 197.8	6.0 2.9			PPP
11	8/11/2025 11:01	DUSTIN PHILLIPS	H-54271 TULSA GAS 2	9.25x51 CNG	CL 03-67	229 C5	3AA-3500 PSI	5833 5847	30	199.2 197.2	2.0 1.0			PPP
12	8/11/2025 11:06	DUSTIN PHILLIPS	H-51499 TULSA GAS 2	9.25x51 CNG	CL 03-67	229 C5	3AA-3500 PSI	5833 5838	30	199.9 195.9	4.0 2.0			PPP
13	8/11/2025 13:12	DUSTIN PHILLIPS	CX-1231-HS TULSA GAS 2	9.25x51 CNG	CL 06/67	229 C5	3AA-3500 PSI	5833 5846	30	195.2 194.2	1.0 0.5			PPP
14	8/11/2025 13:17	DUSTIN PHILLIPS	H-40838 TULSA GAS 2	9.25x51 CNG	CL 11/665	229 C5	3AA-3500 PSI	5833 5853	30	198.5 196.5	2.0 1.0			PPP
15	8/11/2025 13:24	DUSTIN PHILLIPS	CX-4355-HS TULSA GAS 2	9.25x51 CNG	CL 04/68	229 C5	3AA-3500 PSI	5833 5846	30	193.9 191.9	2.0 1.0			PPP
16	8/11/2025 13:30	DUSTIN PHILLIPS	H-50221 TULSA GAS 2	9.25x51 CNG	CL 11-66	229 C5	3AA-3500 PSI	5833 5841	30	200.5 196.5	4.0 2.0			PPP
17	8/11/2025 13:37	DUSTIN PHILLIPS	H-43192 TULSA GAS 2	9.25x51 CNG	CL 01/66	229 C5	3AA-3500 PSI	5833 5846	30	193.1 191.1	2.0 1.0			PPP

#	Test Date Test Time	Operator	Serial Number Cyl Owner	Size Service	Cyl MFG. MFG. Date	REE Source	Rating Unit	Specified Actual	Test Time	Total Elastic	Perm Percen	+* VE	VE Date Ref Ring	Disposition Remark
18	8/11/2025 13:41	DUSTIN PHILLIPS	H-404410 TULSA GAS 2	9.25x51 CNG	CL 09/60	229 C5	3AA-3500 PSI	5833 5840	30	198.0 195.0	3.0 1.5			PPP
19	8/11/2025 13:53	DUSTIN PHILLIPS	CX-4142-HS TULSA GAS 2	9.25x51 CNG	CL 04/68	229 C5	3AA-3500 PSI	5833 5845	30	191.9 189.9	2.0 1.0			PPP
20	8/11/2025 14:09	DUSTIN PHILLIPS	CX-1741-HS TULSA GAS 2	9.25x51 CNG	CL 06/67	229 C5	3AA-3500 PSI	5833 5848	30	196.4 195.4	1.0 0.5			PPP
21	8/11/2025 14:15	DUSTIN PHILLIPS	H-53930 TULSA GAS 2	9.25x51 CNG	CL 04/67	229 C5	3AA-3500 PSI	5833 5840	30	195.8 193.8	2.0 1.0			PPP
22	8/11/2025 14:20	DUSTIN PHILLIPS	H-51683 TULSA GAS 2	9.25x51 CNG	CL 03/67	229 C5	3AA-3500 PSI	5833 5843	30	206.2 203.2	3.0 1.4			PPP