



Tulsa Gas Technologies, Inc.
4809 S. 101st East Ave Tulsa, OK 74146
PHONE: 918-665-2641 FAX: 918-665-2657

2/02/2026

Dispenser Serial Number 25111537

Micro Motion Transmitter Configuration

Required settings for correct operation of Micro Motion mass flow meter.

Transmitter Model Number: 2700
Sensor Model Number: CNG050
Transmitter Serial Number: 12292370
Sensor Serial Number: 15624640
Flow Calibration Factor: 141.674.50
Flow Units: LB/min

Communication on RS-485

Protocol: Modbus ASCII 7 Bit
Modbus Address: 1
Baud Rate: 9600
Parity: Even
Stop Bits: 1

HART Communication

Superimposed on Primary mA (PV)

Analog Output (4-20 mA)

Analog Variable (PV): Mass Flow
Lower Range Value: 0.2500 lb/min
Upper Range Value: 300.000 lb/min
mA Cutoff: 0.0000 lb/min

Freq/Rate

Frequency variable (TV): Mass Flow
Frequency Cutoff: 0.2500 lb/min
Pulses per Unit: 1000.00000 per lb

Temperature

Temp Units: deg F