

| TGT DISPENSER HOSE TEST RESULTS DATE: | |
|---------------------------------------|--------------------|
| Serial Number: | 26011539 |
| Model Number: | T7214-12-12-8CN950 |
| Customer Name: | TRICUM |
| P.O. Number: | |

| HOSE 1 | | | |
|----------|-------|----------|--------|
| | SCALE | CUSTOMER | %ERROR |
| Test 1 | 9.18 | 9.14 | 0.44% |
| Test 2 | 9.55 | 9.51 | 0.42% |
| Test 3 | 10.19 | 10.14 | 0.49% |
| Test 4 | | | |
| Test 5 | | | |
| Test 6 | | | |
| Average: | 9.64 | 9.60 | 0.42% |

| HOSE 2 | | | |
|----------|-------|----------|--------|
| | SCALE | CUSTOMER | %ERROR |
| Test 1 | 9.01 | 9.01 | 0.0% |
| Test 2 | 9.14 | 9.12 | 0.22% |
| Test 3 | 9.07 | 9.04 | 0.33% |
| Test 4 | | | |
| Test 5 | | | |
| Test 6 | | | |
| Average: | 9.07 | 9.06 | 0.11% |