

TGT DISPENSER HOSE TEST RESULTS DATE:	
Serial Number:	26031541
Model Number:	T7203-8CNG50
Customer Name:	SPECIALTY PROCESS EQUIPMENT INC.
P.O. Number:	

HOSE 1			
	SCALE	CUSTOMER	%ERROR
Test 1	11.480	11.509	.25%
Test 2	11.620	11.603	.15%
Test 3	11.480	11.472	.01%
Test 4			
Test 5			
Test 6			
Average:	11.527	11.528	.01%

HOSE 2			
	SCALE	CUSTOMER	%ERROR
Test 1	8.840	8.840	0%
Test 2	8.820	8.801	.22%
Test 3	8.930	8.958	.31%
Test 4			
Test 5			
Test 6			
Average:	8.863	8.866	.03%