

TGT DISPENSER HOSE TEST RESULTS DATE:	
Serial Number:	26071558
Model Number:	T7103-8CN450W
Customer Name:	THOMPSON FACILITIES SERVICES
P.O. Number:	

HOSE 1			
	SCALE	CUSTOMER	%ERROR
Test 1	9.410	9.389	.22
Test 2	9.290	9.249	.44
Test 3	9.290	9.248	.45
Test 4			
Test 5			
Test 6			
Average:	9.330	9.295	.38%

HOSE 2			
	SCALE	CUSTOMER	%ERROR
Test 1			
Test 2			
Test 3			
Test 4			
Test 5			
Test 6			
Average:			