

HOSE 1

Prover Starting Mass	0.0000					
Prover 1st Batch	12.0400					
Dispenser 1st Batch	12.021	0.16 %				
Prover 2nd Batch	23.8300					
Dispenser 2nd Batch	11.784	0.05 %				
Prover 3rd Batch	35.5600					
Dispenser 3rd Batch	11.729	0.01 %				
Prover 4th Batch	0.000					
Dispenser 4th Batch	0.000	100.00 %				
STARTING PROVER READING						
Lb/GGE	0.0000	SCALE	SCALE/GGE	GALLONS	PERCENT of ERROR	NEW GGE FACTOR
1	12.0400	12.0400	12.040	12.021	0.16	1.00
	23.8300	11.7900	11.790	11.784	0.05	
	35.5600	11.7300	11.730	11.729	0.01	
						0.07%

HOSE 2

Prover Starting Mass	0.0000					
Prover 1st Batch	11.2000					
Dispenser 1st Batch	11.257	-0.51 %				
Prover 2nd Batch	22.3300					
Dispenser 2nd Batch	11.226	-0.86 %				
Prover 3rd Batch	33.6600					
Dispenser 3rd Batch	11.388	-0.51 %				
Prover 4th Batch						
Dispenser 4th Batch		100.00 %				
STARTING PROVER READING						
Lb/GGE	0.0000	SCALE	SCALE/GGE	GALLONS	PERCENT of ERROR	NEW GGE FACTOR
1	11.2000	11.2000	11.200	11.257	-0.51	0.99
	22.3300	11.1300	11.130	11.226	-0.86	
	33.6600	11.3300	11.330	11.388	-0.51	
						-0.63%

Tulsa Gas Technologies, Inc.

Calibration Report

4809 South 101st East Ave.
Tulsa, OK 74146
Phone 918-665-2641 Fax 918-665-2657

DATE: March 18, 2021
Test # 1
Test Date: March 17, 2021
Tested By: Garrett Bias/C.R. Kendall
Test Type Acceptance

Test Site:
Tulsa Gas Technologies, Inc.
4809 South 101st East Ave.
Tulsa, OK 74146

CONTACT: Jerry Kelley
PHONE: 918 665 2641

Work Order Number:
JWPC122320

Customer Name:
Tulsa Gas Technologies
4809 South 101st East Ave.
Tulsa, OK. 74146

Dispenser Model Number:
T-7203-8CNG50W

Dispenser Serial Number:
21011306

Eprom Number:
1.04.13RWT 2-6-2015

	SCALE	DISPENSER	PERCENT of ERROR
HOSE 1	MASS/GGE	GGE	
	12.04	12.021	0.16%
	11.79	11.784	0.05%
	11.73	11.729	0.01%
HOSE 2	11.20	11.257	-0.51%
	11.13	11.226	-0.86%
	11.33	11.388	-0.51%

EXPECTABLE TOLERANCE IS + - 2% FOR EACH BATCH
AND + - .8% BETWEEN BATCHES PER EACH HOSE