

CERTIFICATE OF CONFORMANCE  
FOR  
MATERIALS SHIPPED

Tulsa Gas Technologies, Inc. (TGT) hereby certifies that all materials in the manufacture of serial number-21051312 MJKC specifications indicated in drawings, bulletins or specifications as called for on the said purchase order. Test reports are on file with us or with our suppliers for examination and indicate conformance with applicable specification requirements. In production items listed, no direct contact was made with mercury, any of its compounds nor with any mercury containing devices employing a single boundary for containment. Tulsa Gas Technologies, Inc. also certifies that the parts listed and shipped on the date indicated are manufactured in accordance with Parker specifications and quality standards, if applicable, as stated on the drawings or specifications called for on said purchase order. All parts and test conform to AGA I-93.

SIGNED BY:     *c. R. Kendall*    

TITLE: ASSEMBLY

DATE: 6/25/2021

Tulsa Gas Technologies, Inc.  
 4809 S. 101st. E. Ave.  
 Tulsa, OK 74146  
 918-665-2641

Disp. Serial # S/N-21051312  
 Customer Name MJKC  
 Customer PO N/A  
 Date Required 6/24/2021

ASSEMBLY/CERTIFICATION SHEET

	SIGN	DATE
1 <input checked="" type="checkbox"/> Review shop work order versus customer print and history	<u>CK</u>	<u>6/24/2021</u>
2 <input checked="" type="checkbox"/> Component part numbers: _____ Pack dates and/or QC codes _____ 5212103458	<u>CK</u>	<u>6/24/2021</u>
3 <input checked="" type="checkbox"/> ID band number _____ 5CNG6/520N4-0506/0106-68/24-96"	<u>CK</u>	<u>6/24/2021</u>
4 <input checked="" type="checkbox"/> Hose Cut Length _____ 96"	<u>CK</u>	<u>6/24/2021</u>
5 _____ Pre-expansion of hose (if required) Size _____ Remarks: _____		
6 <input checked="" type="checkbox"/> Audit and mark appropriate insertion depth	<u>CK</u>	<u>6/24/2021</u>
7 _____ Add special accessories _____ Remarks: _____		
8 <input checked="" type="checkbox"/> Apply danger tag and ID band		
9 <input checked="" type="checkbox"/> Install bend restrictors _____ Remarks: _____	<u>EN</u>	<u>6/24/2021</u>
10 <input checked="" type="checkbox"/> Assemble fittings; check insertion depth _____ Remarks: _____	<u>CK</u>	<u>6/24/2021</u>
11 _____ Set offset angle and/or orientation _____ Remarks: _____		
12 <input checked="" type="checkbox"/> Perform crimp or swage on product/crimp set die-using Parker Catalog 4660, page K58 _____ 1/2) 80C-PO8H _____ 3/8) 80C-PO6H _____ 1/4) 80C-PO4H _____ 1/2) 80C-PO2 <input checked="" type="checkbox"/> 3/8) 80C-PO6 _____ 3/4) 80C-P12H	<u>CK</u>	<u>6/24/2021</u>
13 _____ Add special accessories after crimping/swaging _____		
14 _____ Perform and record burst test results, if applicable _____ Remarks: _____		
15 _____ Air test, if applicable Test pressure Psi _____ Seconds _____; Pass/Fail (Circle One) Remarks: _____	<u>CK</u>	<u>6/24/2021</u>
16 <input checked="" type="checkbox"/> Hydrostatic proof test Test pressure Psi <u>350</u> Seconds <u>30</u> ; <u>Pass</u> Fail (Circle One) Remarks: <u>Passed Pressure Test</u>	<u>CK</u>	<u>6/24/2021</u>
17 <input checked="" type="checkbox"/> Flush method water, and then air	<u>CK</u>	<u>6/24/2021</u>
18 <input checked="" type="checkbox"/> Perform and record conductivity test; Meter _____ Megger Mit200 Hose resistance <u>0</u> (-) Electrode resistance <u>0.03</u>	<u>CK</u>	<u>6/24/2021</u>
19 <input checked="" type="checkbox"/> Final audit: Check boxes for items inspected, as applicable: _____ <input checked="" type="checkbox"/> Correct hose; _____ <input checked="" type="checkbox"/> Correct fittings; _____ <input checked="" type="checkbox"/> Correct customer PN Check swage or crimp diameters: _____ 5CNG-4-55 .580+-.05 _____ 5CNG-4-58 .785/.805 _____ 5CNG-8-58 .900/.920 <input checked="" type="checkbox"/> 5CNG-6-55 .675/.695 _____ 5CNG-12-58 1.20/1.22 *****100% VISUAL INSPECT FOR THE FOLLOWING***** _____ <input checked="" type="checkbox"/> Hose fittings crimped; _____ <input checked="" type="checkbox"/> Air passes through assembly; _____ <input checked="" type="checkbox"/> Presence of threads	<u>CK</u>	<u>6/24/2021</u>
20 <input checked="" type="checkbox"/> Cap and package hose	<u>CK</u>	<u>6/24/2021</u>
21 <input checked="" type="checkbox"/> Certificate of Conformance for Materials Shipped (on back)	<u>CK</u>	<u>6/24/2021</u>

0.02


- 3 FITTING TYPE
- 01 NPT MALE
- 02 NPT FEMALE
- 03 JIC MALE
- 04 SAE 45 MALE
- 05 SAE O-RING STRAIGHT THREAD
- 06 JIC FEMALE SWIVEL
- 07 FEMALE PIPE SWIVEL

- 1 58 SERIES HOSE SIZE
- 4 1/4"
- 6 3/8"
- 8 1/2"
- 10 5/8"
- 12 3/4"

- 4 FITTING TYPE
- 01 NPT MALE
- 02 NPT FEMALE
- 03 JIC MALE
- 04 SAE 45 MALE
- 05 SAE O-RING STRAIGHT THREAD
- 06 JIC FEMALE SWIVEL
- 07 FEMALE PIPE SWIVEL

- 8 FITTING SIZE
- 4 1/4"
- 6 3/8"
- 8 1/2"
- 12 3/4"

BREAK AWAY END



5 & 9

3 & 7

2 VENT

(1 FILL)

11

FILL HOSE LENGTH

96"

cut 99"

FILL END

4 & 8

6 & 10

- 5 FITTING TYPE
- 01 NPT MALE
- 02 NPT FEMALE
- 03 JIC MALE
- 04 SAE 45 MALE
- 05 SAE O-RING STRAIGHT THREAD
- 06 JIC FEMALE SWIVEL
- 07 FEMALE PIPE SWIVEL

- 2 55 SERIES HOSE SIZE
- 2 1/8"
- 4 1/4"
- 6 3/8"

STANDARD 3" SHEREX 5/8"

6

- FITTING TYPE
- 01 NPT MALE
- 02 NPT FEMALE
- 03 JIC MALE
- 04 SAE 45 MALE
- 05 SAE O-RING STRAIGHT THIRLAD
- 06 JIC FEMALE SWIVEL
- 07 FEMALE PIPE SWIVEL

- 10 FITTING SIZE
- 2 1/8"
- 4 1/4"
- 6 3/8"

WORK ORDER # <sup>5/11-21051312</sup> MJJK 0030021

5CNG6/520N4-0506/0106-68/24-96

FILL HOSE

DATE 03/27/97  
BY GUYEN DUBOIS E. GUYEN

THE NATIONAL HOSE WORKS COMPANY  
1100 W. 10TH STREET  
TULSA, OK 74106  
DISTRIBUTION FAX 918-486-3821  
TULSA, OK 74106

CERTIFICATE OF CONFORMANCE  
FOR  
MATERIALS SHIPPED

Tulsa Gas Technologies, Inc. (TGT) hereby certifies that all materials in the manufacture of serial number-21051312 MJKC specifications indicated in drawings, bulletins or specifications as called for on the said purchase order. Test reports are on file with us or with our suppliers for examination and indicate conformance with applicable specification requirements. In production items listed, no direct contact was made with mercury, any of its compounds nor with any mercury containing devices employing a single boundary for containment. Tulsa Gas Technologies, Inc. also certifies that the parts listed and shipped on the date indicated are manufactured in accordance with Parker specifications and quality standards, if applicable, as stated on the drawings or specifications called for on said purchase order. All parts and test conform to AGA I-93.

SIGNED BY: *e. R. Rendall*

TITLE: ASSEMBLY

DATE: 6/25/2021

Tulsa Gas Technologies, Inc.  
 4809 S. 101st. E. Ave.  
 Tulsa, OK 74146  
 918-665-2641

Disp. Serial # S/N-21051312  
 Customer Name MJKC  
 Customer PO N/A  
 Date Required 6/24/2021

ASSEMBLY/CERTIFICATION SHEET

	SIGN	DATE
1 <input checked="" type="checkbox"/> Review shop work order versus customer print and history	<u>ck</u>	<u>6/24/2021</u>
2 <input checked="" type="checkbox"/> Component part numbers: _____ Pack dates and/or QC codes _____ 5212103459	<u>ck</u>	<u>6/24/2021</u>
3 <input checked="" type="checkbox"/> ID band number _____ 5CNG6/520N4-0506/0106-68/24-24"	<u>ck</u>	<u>6/24/2021</u>
4 <input checked="" type="checkbox"/> Hose Cut Length _____ 24"	<u>ck</u>	<u>6/24/2021</u>
5 _____ Pre-expansion of hose (if required) Size _____ Remarks: _____		
6 <input checked="" type="checkbox"/> Audit and mark appropriate insertion depth	<u>ck</u>	<u>6/24/2021</u>
7 _____ Add special accessories _____ Remarks: _____		
8 <input checked="" type="checkbox"/> Apply danger tag and ID band		
9 <input checked="" type="checkbox"/> Install bend restrictors Remarks: _____	<u>ck</u>	<u>6/24/2021</u>
10 <input checked="" type="checkbox"/> Assemble fittings; check insertion depth Remarks: _____	<u>ck</u>	<u>6/24/2021</u>
11 _____ Set offset angle and/or orientation Remarks: _____		
12 <input checked="" type="checkbox"/> Perform crimp or swage on product/crimp set die-using Parker Catalog 4660, page K58 _____ 1/2) 80C-PO8H _____ 3/8) 80C-PO6H _____ 1/4) 80C-PO4H _____ 1/2) 80C-PO2 <input checked="" type="checkbox"/> 3/8) 80C-PO6 _____ 3/4) 80C-P12H	<u>ck</u>	<u>6/24/2021</u>
13 _____ Add special accessories after crimping/swaging _____		
14 _____ Perform and record burst test results, if applicable Remarks: _____		
15 _____ Air test, if applicable Test pressure Psi _____ Seconds _____ ; Pass/Fail (Circle One) Remarks: _____	<u>ck</u>	<u>6/24/2021</u>
16 <input checked="" type="checkbox"/> Hydrostatic proof test Test pressure Psi <u>350</u> Seconds <u>30</u> ; Pass/Fail (Circle One) Remarks: _____	<u>ck</u>	<u>6/24/2021</u>
17 <input checked="" type="checkbox"/> Flush method water, and then air	<u>ck</u>	<u>6/24/2021</u>
18 <input checked="" type="checkbox"/> Perform and record conductivity test; Meter _____ Megger Mit200 Hose resistance _____ 0 _____ (-) Electrode resistance _____ 0.01 0.01	<u>ck</u>	<u>6/24/2021</u>
19 <input checked="" type="checkbox"/> Final audit: Check boxes for items inspected, as applicable: <input checked="" type="checkbox"/> Correct hose; <input checked="" type="checkbox"/> Correct fittings; <input checked="" type="checkbox"/> Correct customer PN Check swage or crimp diameters: _____ 5CNG-4-55 .580+-.05 _____ 5CNG-4-58 .785/.805 _____ 5CNG-8-58 .900/.920 <input checked="" type="checkbox"/> 5CNG-6-55 .675/.695 _____ 5CNG-12-58 1.20/1.22	<u>ck</u>	<u>6/24/2021</u>
*****100% VISUAL INSPECT FOR THE FOLLOWING*****		
<input checked="" type="checkbox"/> Hose fittings crimped; <input checked="" type="checkbox"/> Air passes through assembly;		
<input checked="" type="checkbox"/> Presence of threads	<u>ck</u>	<u>6/24/2021</u>
20 <input checked="" type="checkbox"/> Cap and package hose	<u>ck</u>	<u>6/24/2021</u>
21 <input checked="" type="checkbox"/> Certificate of Conformance for Materials Shipped (on back)	<u>ck</u>	<u>6/24/2021</u>

- 3 FITTING TYPE  
01 NPT MALE  
02 NPT FEMALE  
03 JIC MALE  
04 SAE 45 MALE  
05 SAE O-RING STRAIGHT THREAD  
06 JIC FEMALE SWIVEL  
07 FEMALE PIPE SWIVEL
- 7 FITTING SIZE  
4 1/4"  
6 3/8"  
8 1/2"


- 1 55 SERIES  
HOSE SIZE  
4 1/4"  
6 3/8"  
8 1/2"  
10 5/8"  
12 3/4"

- 4 FITTING TYPE  
01 NPT MALE  
02 NPT FEMALE  
03 JIC MALE  
04 SAE 45 MALE  
05 SAE O-RING STRAIGHT THREAD  
06 JIC FEMALE SWIVEL  
07 FEMALE PIPE SWIVEL
- 8 FITTING SIZE  
4 1/4"  
6 3/8"  
8 1/2"  
12 3/4"

BREAK AWAY END

11 FILL HOSE LENGTH  
24"

cut + 26"



- 5 FITTING TYPE  
01 NPT MALE  
02 NPT FEMALE  
03 JIC MALE  
04 SAE 45 MALE  
05 SAE O-RING STRAIGHT THREAD  
06 JIC FEMALE SWIVEL  
07 FEMALE PIPE SWIVEL
- 9 FITTING SIZE  
2 1/8"  
4 1/4"  
6 3/8"

- 2 55 SERIES  
HOSE SIZE  
2 1/8"  
4 1/4"  
6 3/8"

- 6 FITTING TYPE  
01 NPT MALE  
02 NPT FEMALE  
03 JIC MALE  
04 SAE 45 MALE  
05 SAE O-RING STRAIGHT THREAD  
06 JIC FEMALE SWIVEL  
07 FEMALE PIPE SWIVEL
- 10 FITTING SIZE  
2 1/8"  
4 1/4"  
6 3/8"

S/N 21051312  
MJK C630021

WORK ORDER # 5CNG1/520N4-0506/0106-68/24-24"

2 3 4 5 6 7 8 9 10 11  
-0506/0106-68/24-24"

FILL HOSE

DATE 03/27/97  
BY SHERIDY C. SWEET  
DISPATCHED BY

THE SHERIDY COMPANY, INC.  
10117 EAST 48TH STREET  
TULSA, OK 74148  
OKLAHOMA TAX ID# 018-000-2067  
SHERIDY

CERTIFICATE OF CONFORMANCE  
FOR  
MATERIALS SHIPPED

Tulsa Gas Technologies, Inc. (TGT) hereby certifies that all materials in the manufacture of serial number-21051312 MJKC specifications indicated in drawings, bulletins or specifications as called for on the said purchase order. Test reports are on file with us or with our suppliers for examination and indicate conformance with applicable specification requirements. In production items listed, no direct contact was made with mercury, any of its compounds nor with any mercury containing devices employing a single boundary for containment. Tulsa Gas Technologies, Inc. also certifies that the parts listed and shipped on the date indicated are manufactured in accordance with Parker specifications and quality standards, if applicable, as stated on the drawings or specifications called for on said purchase order. All parts and test conform to AGA I-93.

SIGNED BY: *C. R. Rendall*

TITLE: ASSEMBLY

DATE: 6/25/2021

Tulsa Gas Technologies, Inc.  
 4809 S. 101st. E. Ave.  
 Tulsa, OK 74146  
 918-665-2641

Disp. Serial # S/N-21051312  
 Customer Name MJKC  
 Customer PO N/A  
 Date Required 6/24/2021

ASSEMBLY/CERTIFICATION SHEET

	SIGN	DATE
1 <input checked="" type="checkbox"/> Review shop work order versus customer print and history	<u>CK</u>	<u>6/24/2021</u>
2 <input checked="" type="checkbox"/> Component part numbers: _____ Pack dates and/or QC codes _____ 5212103457	<u>CK</u>	<u>6/24/2021</u>
3 <input checked="" type="checkbox"/> ID band number _____ 5CNG6/520N4-0506/0106-68/24-96"	<u>CK</u>	<u>6/24/2021</u>
4 <input checked="" type="checkbox"/> Hose Cut Length _____ 96"	<u>CK</u>	<u>6/24/2021</u>
5 _____ Pre-expansion of hose (if required) Size _____ Remarks: _____		
6 <input checked="" type="checkbox"/> Audit and mark appropriate insertion depth	<u>CK</u>	<u>6/24/2021</u>
7 _____ Add special accessories _____ Remarks: _____		
8 <input checked="" type="checkbox"/> Apply danger tag and ID band		
9 <input checked="" type="checkbox"/> Install bend restrictors _____ Remarks: _____	<u>CK</u>	<u>6/24/2021</u>
10 <input checked="" type="checkbox"/> Assemble fittings; check insertion depth _____ Remarks: _____	<u>CK</u>	<u>6/24/2021</u>
11 _____ Set offset angle and/or orientation _____ Remarks: _____		
12 <input checked="" type="checkbox"/> Perform crimp or swage on product/crimp set die-using Parker Catalog 4660, page K58 _____ 1/2) 80C-PO8H _____ 3/8) 80C-PO6H _____ 1/4) 80C-PO4H _____ 1/2) 80C-PO2 <input checked="" type="checkbox"/> 3/8) 80C-PO6 _____ 3/4) 80C-P12H	<u>CK</u>	<u>6/24/2021</u>
13 _____ Add special accessories after crimping/swaging _____		
14 _____ Perform and record burst test results, if applicable _____ Remarks: _____		
15 _____ Air test, if applicable Test pressure Psi _____ Seconds _____ ; Pass/Fail (Circle One) Remarks: _____	<u>CK</u>	<u>6/24/2021</u>
16 <input checked="" type="checkbox"/> Hydrostatic proof test Test pressure Psi <u>350</u> Seconds <u>30</u> <input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail (Circle One) Remarks: <u>Pass and pressure test</u>	<u>CK</u>	<u>6/24/2021</u>
17 <input checked="" type="checkbox"/> Flush method water, and then air	<u>CK</u>	<u>6/24/2021</u>
18 <input checked="" type="checkbox"/> Perform and record conductivity test; Meter _____ Megger Mit200 Hose resistance _____ 0 _____ (-) Electrode resistance _____ 0.03 0.03	<u>CK</u>	<u>6/24/2021</u>
19 <input checked="" type="checkbox"/> Final audit: Check boxes for items inspected, as applicable: _____ <input checked="" type="checkbox"/> Correct hose; _____ <input checked="" type="checkbox"/> Correct fittings; _____ <input checked="" type="checkbox"/> Correct customer PN Check swage or crimp diameters: _____ 5CNG-4-55 .580+-.05 _____ 5CNG-4-58 .785/.805 _____ 5CNG-8-58 .900/.920 <input checked="" type="checkbox"/> 5CNG-6-55 .675/.695 _____ 5CNG-12-58 1.20/1.22 *****100% VISUAL INSPECT FOR THE FOLLOWING***** _____ <input checked="" type="checkbox"/> Hose fittings crimped; _____ <input checked="" type="checkbox"/> Air passes through assembly; _____ <input checked="" type="checkbox"/> Presence of threads	<u>CK</u>	<u>6/24/2021</u>
20 <input checked="" type="checkbox"/> Cap and package hose	<u>CK</u>	<u>6/24/2021</u>
21 <input checked="" type="checkbox"/> Certificate of Conformance for Materials Shipped (on back)	<u>CK</u>	<u>6/24/2021</u>



0.02


- 3 FITTING TYPE
- 01 NPT MALE
- 02 NPT FEMALE
- 03 JIC MALE
- 04 SAE 45 MALE
- 05 SAE O-RING STRAIGHT THREAD
- 06 JIC FEMALE SWIVEL
- 07 FEMALE PIPE SWIVEL

- 1 58 SERIES HOSE SIZE
- 4 1/4"
- 6 3/8"
- 8 1/2"
- 10 5/8"
- 12 3/4"

- 4 FITTING TYPE
- 01 NPT MALE
- 02 NPT FEMALE
- 03 JIC MALE
- 04 SAE 45 MALE
- 05 SAE O-RING STRAIGHT THREAD
- 06 JIC FEMALE SWIVEL
- 07 FEMALE PIPE SWIVEL

- 8 FITTING SIZE
- 4 1/4"
- 6 3/8"
- 8 1/2"
- 12 3/4"

BREAK AWAY END



cut 99"

11 FILL HOSE LENGTH

96"

(1 FILL)

2 VENT

FILL END

4 & 8

5 & 9

(6 & 10

STANDARD 3" SHEREX 5/8" 5/8

- 5 FITTING TYPE
- 01 NPT MALE
- 02 NPT FEMALE
- 03 JIC MALE
- 04 SAE 45 MALE
- 05 SAE O-RING STRAIGHT THREAD
- 06 JIC FEMALE SWIVEL
- 07 FEMALE PIPE SWIVEL

- 2 55 SERIES HOSE SIZE
- 2 1/8"
- 4 1/4"
- 6 3/8"

- 6 FITTING TYPE
- 01 NPT MALE
- 02 NPT FEMALE
- 03 JIC MALE
- 04 SAE 45 MALE
- 05 SAE O-RING STRAIGHT THRLAD
- 06 JIC FEMALE SWIVEL
- 07 FEMALE PIPE SWIVEL

- 10 FITTING SIZE
- 2 1/8"
- 4 1/4"
- 6 3/8"

5/11 - 21051312

WORK ORDER # MJJK 0030021

1 5CNG6/520N4-0506/0106-68/24-96/

2 3 4 5 6 7 8 9 10 11

FILL HOSE

DATE 03/27/97

THE COMPANY FOR THE...  
1100 EAST MAIN STREET  
TULSA, OK 74106  
918 486-3861 FAX 918 486-3861  
COURTESY C. G. WELLS

CERTIFICATE OF CONFORMANCE  
FOR  
MATERIALS SHIPPED

Tulsa Gas Technologies, Inc. (TGT) hereby certifies that all materials in the manufacture of serial number-21051312 MJKC specifications indicated in drawings, bulletins or specifications as called for on the said purchase order. Test reports are on file with us or with our suppliers for examination and indicate conformance with applicable specification requirements. In production items listed, no direct contact was made with mercury, any of its compounds nor with any mercury containing devices employing a single boundary for containment. Tulsa Gas Technologies, Inc. also certifies that the parts listed and shipped on the date indicated are manufactured in accordance with Parker specifications and quality standards, if applicable, as stated on the drawings or specifications called for on said purchase order. All parts and test conform to AGA I-93.

SIGNED BY:           *C. R. Kendall*          

TITLE: ASSEMBLY

DATE: 6/25/2021

Tulsa Gas Technologies, Inc.  
 4809 S. 101st. E. Ave.  
 Tulsa, OK 74146  
 918-665-2641

Disp. Serial # S/N-21051312  
 Customer Name MJKC  
 Customer PO N/A  
 Date Required 6/24/2021

ASSEMBLY/CERTIFICATION SHEET

		SIGN	DATE
1	<input checked="" type="checkbox"/> Review shop work order versus customer print and history	<u>CK</u>	<u>6/24/2021</u>
2	<input checked="" type="checkbox"/> Component part numbers: _____ Pack dates and/or QC codes _____ 5212103457	<u>CK</u>	<u>6/24/2021</u>
3	<input checked="" type="checkbox"/> ID band number _____ 5CNG6/520N4-0506/0106-68/24-24"	<u>CK</u>	<u>6/24/2021</u>
4	<input checked="" type="checkbox"/> Hose Cut Length _____ 24"	<u>CK</u>	<u>6/24/2021</u>
5	<input type="checkbox"/> Pre-expansion of hose (if required) Size _____ Remarks: _____		
6	<input checked="" type="checkbox"/> Audit and mark appropriate insertion depth	<u>CK</u>	<u>6/24/2021</u>
7	<input type="checkbox"/> Add special accessories _____ Remarks: _____		
8	<input checked="" type="checkbox"/> Apply danger tag and ID band		
9	<input checked="" type="checkbox"/> Install bend restrictors Remarks: _____	<u>CK</u>	<u>6/24/2021</u>
10	<input checked="" type="checkbox"/> Assemble fittings; check insertion depth Remarks: _____	<u>CK</u>	<u>6/24/2021</u>
11	<input type="checkbox"/> Set offset angle and/or orientation Remarks: _____		
12	<input checked="" type="checkbox"/> Perform crimp or swage on product/crimp set die-using Parker Catalog 4660, page K58 _____ 1/2) 80C-PO8H _____ 3/8) 80C-PO6H _____ 1/4) 80C-PO4H _____ 1/2) 80C-PO2 <input checked="" type="checkbox"/> 3/8) 80C-PO6 _____ 3/4) 80C-P12H	<u>CK</u>	<u>6/24/2021</u>
13	<input type="checkbox"/> Add special accessories after crimping/swaging _____		
14	<input type="checkbox"/> Perform and record burst test results, if applicable Remarks: _____		
15	<input type="checkbox"/> Air test, if applicable Test pressure Psi _____ Seconds _____ ; Pass/Fail (Circle One) Remarks: _____	<u>CK</u>	<u>6/24/2021</u>
16	<input checked="" type="checkbox"/> Hydrostatic proof test Test pressure Psi <u>350</u> Seconds <u>30</u> <u>Pass</u> Fail (Circle One) Remarks: <u>Pass at Pressure Test</u>	<u>CK</u>	<u>6/24/2021</u>
17	<input checked="" type="checkbox"/> Flush method water, and then air	<u>CK</u>	<u>6/24/2021</u>
18	<input checked="" type="checkbox"/> Perform and record conductivity test; Meter _____ Megger Mit200 Hose resistance _____ 0 _____ (-) Electrode resistance _____ 0.01 0.01	<u>CK</u>	<u>6/24/2021</u>
19	<input checked="" type="checkbox"/> Final audit: Check boxes for items inspected, as applicable: <input checked="" type="checkbox"/> Correct hose; <input checked="" type="checkbox"/> Correct fittings; <input checked="" type="checkbox"/> Correct customer PN Check swage or crimp diameters: _____ 5CNG-4-55 .580+-.05 _____ 5CNG-4-58 .785/.805 _____ 5CNG-8-58 .900/.920 <input checked="" type="checkbox"/> 5CNG-6-55 .675/.695 _____ 5CNG-12-58 1.20/1.22 *****100% VISUAL INSPECT FOR THE FOLLOWING***** <input checked="" type="checkbox"/> Hose fittings crimped; <input checked="" type="checkbox"/> Air passes through assembly; <input checked="" type="checkbox"/> Presence of threads	<u>CK</u>	<u>6/24/2021</u>
20	<input checked="" type="checkbox"/> Cap and package hose	<u>CK</u>	<u>6/24/2021</u>
21	<input checked="" type="checkbox"/> Certificate of Conformance for Materials Shipped (on back)	<u>CK</u>	<u>6/24/2021</u>

0.01

- 3 FITTING TYPE
- 01 NPT MALE
- 02 NPT FEMALE
- 03 JIC MALE
- 04 SAE 45 MALE
- 05 SAE O-RING STRAIGHT THREAD
- 06 JIC FEMALE SWIVEL
- 07 FEMALE PIPE SWIVEL

- 1 55 SERIES
- HOSE SIZE
- 4 1/4"
- 6 3/8"
- 8 1/2"
- 10 5/8"
- 12 3/4"

- 4 FITTING TYPE
- 01 NPT MALE
- 02 NPT FEMALE
- 03 JIC MALE
- 04 SAE 45 MALE
- 05 SAE O-RING STRAIGHT THREAD
- 06 JIC FEMALE SWIVEL
- 07 FEMALE PIPE SWIVEL

8

- FITTING SIZE
- 4 1/4"
- 6 3/8"
- 8 1/2"
- 12 3/4"

BREAK AWAY END

FILL END

C4 + 26"

11

FILL HOSE LENGTH

24"

3 & 7

(1 FILL)

5 & 9

2 VENT

4 & 8

6 & 10

STANDARD 3" SHEREX 5/8"

5/8

- 5 FITTING TYPE
- 01 NPT MALE
- 02 NPT FEMALE
- 03 JIC MALE
- 04 SAE 45 MALE
- 05 SAE O-RING STRAIGHT THREAD
- 06 JIC FEMALE SWIVEL
- 07 FEMALE PIPE SWIVEL

- 2 55 SERIES
- HOSE SIZE
- 2 1/8"
- 4 1/4"
- 6 3/8"

- 6 FITTING TYPE
- 01 NPT MALE
- 02 NPT FEMALE
- 03 JIC MALE
- 04 SAE 45 MALE
- 05 SAE O-RING STRAIGHT THREAD
- 06 JIC FEMALE SWIVEL
- 07 FEMALE PIPE SWIVEL

10

- FITTING SIZE
- 2 1/8"
- 4 1/4"
- 6 3/8"

S/N 21051312

WORK ORDER #

5CNG 1/520N 4-0506 / 0106 - 68 / 24 - 24"

FILL HOSE

DATE 01/27/97  
BY GIBBORDY G. SEWELL

FOR INFORMATION ONLY  
THIS IS NOT A CONTRACT  
OUR BEST PRICE IS OUR BEST  
OFFER