

TGT DISPENSER HOSE TEST RESULTS

Serial Number:	21051312	DATE:	06-30-21	TIME:	
Model Number:	T7203-8CN650W				
Customer Name:	MJK Construction				
P.O. Number:	MJKCO33021				

<i>scale</i>		HOSE 1	
	TGT (prover)	CUSTOMER	% ERROR
Test 1:	11.48	11.58	0.87%
Test 2:	11.77	11.831	0.33%
Test 3:	11.01	11.006	0.04%
Test 4:			
Test 5:			
Test 6:			
Average:			0.41%

<i>scale</i>		HOSE 2	
	TGT (prover)	CUSTOMER	% ERROR
Test 1:	10.64	10.65	0.09%
Test 2:	11.24	11.28	0.36% 0.36%
Test 3:	12.08	12.16	0.66%
Test 4:			
Test 5:			
Test 6:			
Average:			