

TGT DISPENSER HOSE TEST RESULTS

Serial Number:	22061327	DATE:	7-6-22	TIME:	11:30
Model Number:	TGT-T7203-12-8-CNG50				
Customer Name:	J.W. POWER				
P.O. Number:	P1291327				

HOSE 1			
	TGT (prover)	CUSTOMER	% ERROR
Test 1:	11.460	11.446	.1221
Test 2:	11.400	11.356	.3859
Test 3:	11.550	11.516	.2943
Test 4:			
Test 5:			
Test 6:			
Average:	11.470	11.439	.2674

HOSE 2			
	TGT (prover)	CUSTOMER	% ERROR
Test 1:	11.350	11.378	-.2466
Test 2:	11.380	11.380	0
Test 3:	11.500	11.482	.1565
Test 4:			
Test 5:			
Test 6:			
Average:	11.410	11.413	.0300