


- A1-3.....BI-TORQ ACTUATOR WITH 1/2" OASIS BALL VALVE
- A4-6.....BI-TORQ ACTUATOR WITH 1/2" OASIS BALL VALVE
- BDV1,2.....BLEED VALVE, PARKER
- BV1.....PARKER 1/2" BALL VALVE, 62 SERIES
- BV2.....OASIS 3/4" BALL VALVE
- CV1-3.....OASIS CHECK VALVE, 1/2", CV304-6NXDN
- CV4-6.....OASIS CHECK VALVE, 3/4", CV306-6NXDP
- CV7.....OASIS CHECK VALVE, 3/8", CV203-4NDSN
- CV8.....OASIS CHECK VALVE, 1/4", CV102-3NBSO
- H1.....HOSE, PARKER PARFLEX 1/2"
- H2.....HOSE, PARKER PARFLEX 3/4"
- ILB1,2.....INLINE BREAKAWAY, OPW ILB5
- M1,2.....METER, MICRO MOTION SENSOR MM-CNG50S290NCAAEZZZ
MICRO MOTION TRANSMITTER MM-2700I13ABEZZZ
- NV1,2,3.....NEEDLE VALVE, NOSHOK
- NZ1.....NOZZLE OPW CT1000
- NZ2.....NOZZLE OPW CT5000
- PSIG1,2.....TGT 2.5" GAUGE 5000PSI
- PSIG3.....NOSHOK, SERIES 900 0-200PSI
- PS1,PS2.....NASON PRESSURE SENSOR, CD-1C-45000R/WL293
- PT1,PT2.....ASHCROFT PRESSURE TRANSMITTER, G27M02RMG35000#G
- REG.....BELGAS REGULATOR, MODEL P39, 0-225
- RV1,RV2.....MERCER RELIEF VALVE, 14-22B7112JX1, 4500lb
- VLB1.....VENT LINE BREAKAWAY TGT ILB6
- VLB2.....VENT LINE BREAKAWAY OPW ILB-5
- S1-6.....ASCO RED HAT SOLENOID VALVE
- SPV1.....KINGSTON LOW PROFILE SAFETY PRESSURE VALVE KSV10, 150PSI



TULSA GAS TECHNOLOGIES, INC.
 4809 South 101st East Avenue
 Tulsa, OK 74146
 (918) 665-2641 FAX: (918) 665-2657

MODEL: -	DRAWN BY: TC	DATE
SEQUENCE -	CHECKED BY: -	06-14-22
PROGRAM: -	APPROVED BY: -	
SERIAL NO.: -	PART: -	
WORK ORDER: -	DWG. NO. T7203-12-8-CNG50W P&ID	