

TGT DISPENSER HOSE TEST RESULTS

Serial Number:	22071328	DATE:	8-10-22	TIME:	12:00
Model Number:	T7103-8CNG50W				
Customer Name:	REVOLUTION CNG				
P.O. Number:	REV0122821				

HOSE 1			
	TGT (prover)	CUSTOMER	% ERROR
Test 1:			
Test 2:			
Test 3:			
Test 4:			
Test 5:			
Test 6:			
Average:			

HOSE 2			
	TGT (prover)	CUSTOMER	% ERROR
Test 1:	11.300	11.275	.221
Test 2:	11.210	11.166	.392
Test 3:	11.480	11.443	.322
Test 4:			
Test 5:			
Test 6:			
Average:	11.330	11.294	.311