

TGT DISPENSER HOSE TEST RESULTS DATE:	
Serial Number:	23041413
Model Number:	TGT-T7203-8CMG50-W
Customer Name:	Probe Alt Fuels
P.O. Number:	1373

HOSE 1			
	SCALE	CUSTOMER	%ERROR
Test 1	12.510	12.482	.223
Test 2	12.470	12.423	.376
Test 3	12.240	12.204	.294
Test 4			
Test 5			
Test 6			
Average:	12.406	12.369	.297

HOSE 2			
	SCALE	CUSTOMER	%ERROR
Test 1	12.110	12.100	.082
Test 2	12.330	12.293	.300
Test 3	12.380	12.342	.306
Test 4			
Test 5			
Test 6			
Average:	12.273	12.245	.229