

TGT DISPENSER HOSE TEST RESULTS

Serial Number:	23041417	DATE:	3-18-24	TIME:	12:30
Model Number:	TGT T7104-12CNG				
Customer Name:	TRILLIUM				
P.O. Number:	TRIL030722				

	SCALE	HOSE 2	
	TGT (prover)	CUSTOMER DSP	% ERROR
Test 1:	10.510	10.494	0.152
Test 2:	10.750	10.756	-0.055
Test 3:	10.960	10.932	0.255
Test 4:			
Test 5:			
Test 6:			
Average:	10.740	10.727	0.121

	HOSE 2		
	TGT (prover)	CUSTOMER	% ERROR
Test 1:			
Test 2:			
Test 3:			
Test 4:			
Test 5:			
Test 6:			
Average:			