



Specification of unit:
 Idec SmartRelay
 FL1F-H12RCC
 100-240V AC/DC
 Output 4xRELAY/10A
 Ethernet port
 LED display
 S/N V-R6A0TC6Q
 Program version: 1.00

- ① STATUS: ACTIVE OR STANDBY
- ② CURRENT TIME ELAPSED
- ③ REMAINING CYCLE TIME
- ④ CYCLE TIME IN SECONDS

TIME IS ADJUSTED IN 15 SECOND INCREMENTS
 TO ADJUST TIME:

HOLD THE [ESC] BUTTON WHILE PRESSING
 ▲ TO INCREASE OR ▼ TO DECREASE.



TULSA GAS TECHNOLOGIES, INC.
 4809 South 101st East Avenue
 Tulsa, OK 74146
 (918) 665-2641 FAX: (918) 665-2657

MODEL:	-	DRAWN BY:	MB	DATE:	
SEQUENCE:	-	CHECKED BY:	-		06-31-23
PROGRAM:	-	APPROVED BY:	-		
SERIAL NO.:	-	PART:	-		
WORK ORDER:	-	DWG. NO.	Time Fill Buffer Control Panel Wiring		
MATERIAL:	-				