

TGT DISPENSER HOSE TEST RESULTS

Serial Number:	23081429	DATE:	3-8-24	TIME:	4:00
Model Number:	T7204-12-12-8 CNG 50-HD-LD				
Customer Name:	TRILLIUM				
P.O. Number:	TRIL012523				

	SCALE	HOSE 1 DISPENSER	
	TGT (prover)	CUSTOMER	% ERROR
Test 1:	11.960	11.974	-.117
Test 2:	12.040	12.058	-.149
Test 3:	11.98	11.950	.250
Test 4:			
Test 5:			
Test 6:			
Average:	11.993	11.994	-.008

	SCALE	HOSE 2 DISPENSER	
	TGT (prover)	CUSTOMER	% ERROR
Test 1:	11.940	11.920	.167
Test 2:	12.140	12.162	-.181
Test 3:	12.280	12.286	-.048
Test 4:			
Test 5:			
Test 6:			
Average:	12.120	12.122	-.016

TGT DISPENSER HOSE TEST RESULTS DATE:	
Serial Number:	23081430 3-7-24
Model Number:	T7204-12-12-8CNG50-HD-LD
Customer Name:	TRILLIUM
P.O. Number:	TRIL012523

HOSE 1			
	SCALE	CUSTOMER	%ERROR
Test 1	12.170	12.220	-.410
Test 2	12.280	12.238	.342
Test 3	12.560	12.552	.065
Test 4			
Test 5			
Test 6			
Average:	12.336	12.336	0

HOSE 2			
	SCALE	CUSTOMER	%ERROR
Test 1	12.720	12.782	-.487
Test 2	12.790	12.844	-.422
Test 3	11.890	11.884	.050
Test 4			
Test 5			
Test 6			
Average:	12.466	12.503	.296