

TGT DISPENSER HOSE TEST RESULTS DATE:	
Serial Number:	23081430 3-7-24
Model Number:	T7204-12-12-8CNG50-HD-LD
Customer Name:	TRILLIUM
P.O. Number:	TRIL012523

HOSE 1			
	SCALE	CUSTOMER	%ERROR
Test 1	12.170	12.220	-.410
Test 2	12.280	12.238	.342
Test 3	12.560	12.552	.065
Test 4			
Test 5			
Test 6			
<b>Average:</b>	12.336	12.336	0

HOSE 2			
	SCALE	CUSTOMER	%ERROR
Test 1	12.720	12.782	-.487
Test 2	12.790	12.844	-.422
Test 3	11.890	11.884	.050
Test 4			
Test 5			
Test 6			
<b>Average:</b>	12.466	12.503	.296