

TGT DISPENSER HOSE TEST RESULTS DATE:	
Serial Number:	23101432
Model Number:	T7104-126NG50
Customer Name:	TRILLIUM
P.O. Number:	TR12021723

HOSE 1			
	SCALE	CUSTOMER	%ERROR
Test 1			
Test 2			
Test 3			
Test 4			
Test 5			
Test 6			
Average:			

HOSE 2			
	SCALE	CUSTOMER	%ERROR
Test 1	12.200	12.202	.016
Test 2	11.860	11.812	.404
Test 3	12.210	12.198	.098
Test 4			
Test 5			
Test 6			
Average:	12.09	12.070	.165