

TGT DISPENSER HOSE TEST RESULTS DATE:	
Serial Number:	23101433
Model Number:	T7104 - 12 CNG50
Customer Name:	TRILLIUM
P.O. Number:	TRIL021723

HOSE 1			
	SCALE	CUSTOMER	%ERROR
Test 1			
Test 2			
Test 3			
Test 4			
Test 5			
Test 6			
Average:			

HOSE 2			
	SCALE	CUSTOMER	%ERROR
Test 1	11.490	11.508	.156
Test 2	11.300	11.312	.106
Test 3	11.680	11.684	.034
Test 4			
Test 5			
Test 6			
Average:	11.490	11.501	.095