

TGT DISPENSER HOSE TEST RESULTS DATE:	
Serial Number:	23101436
Model Number:	T7203 - 8CNG50
Customer Name:	SPECIALTY PROCESS EQUIPMENT
P.O. Number:	15200

HOSE 1			
	SCALE	CUSTOMER	%ERROR
Test 1	12.830	12.786	.343
Test 2	12.930	12.881	.378
Test 3	12.900	12.864	.279
Test 4			
Test 5			
Test 6			
<b>Average:</b>	12.886	12.843	.333

HOSE 2			
	SCALE	CUSTOMER	%ERROR
Test 1	12.140	12.195	-.453
Test 2	12.010	12.039	-.241
Test 3	11.990	12.040	-.417
Test 4			
Test 5			
Test 6			
<b>Average:</b>	12.046	12.091	-.373