

TGT DISPENSER HOSE TEST RESULTS DATE:	
Serial Number:	23121439
Model Number:	T7103 - 12 CNG E.H.
Customer Name:	J.W. POWER COMPANY
P.O. Number:	JWPC062223

HOSE 1			
	SCALE	CUSTOMER	%ERROR
Test 1	11.720	11.678	.358
Test 2	12.380	12.338	.339
Test 3	12.022	12.080	-.482
Test 4			
Test 5			
Test 6			
<b>Average:</b>	12.040	12.032	-.066

HOSE 2			
	SCALE	CUSTOMER	%ERROR
Test 1			
Test 2			
Test 3			
Test 4			
Test 5			
Test 6			
<b>Average:</b>			