

TGT DISPENSER HOSE TEST RESULTS DATE:	
Serial Number:	24091474
Model Number:	T7204 - 8CN450W
Customer Name:	MIDWEST CLEAN FUELS CRAWFORDSVILLE, IN
P.O. Number:	

HOSE 1			
	SCALE	CUSTOMER	%ERROR
Test 1	10.590	10.559	.294%
Test 2	10.470	10.475	.048%
Test 3	10.540	10.519	.200%
Test 4			
Test 5			
Test 6			
Average:			

HOSE 2			
	SCALE	CUSTOMER	%ERROR
Test 1	10.690	10.695	.047%
Test 2	10.670	10.658	.113%
Test 3	10.780	10.786	.056%
Test 4			
Test 5			
Test 6			
Average:			