

Cylinder Regualification Report

DOT/TC Registration #

Galiso, Inc

22 Ponderosa Ct.

Montrose, CO 81401

NM Gas Co: 3 Trailers-5 ea

Code Has Three Letters: 1st Letter: Visual Test, 2nd Letter: % Perm Exp Test, 3rd Letter: REE Test
Letter Code: P=Passed, F=Failed, N=Not Applicable, A=Aborted **Example:** PPP-Passed Visual, Passed % Perm, Passed REE
PCAL, FCAL used for passed, failed calibration verification test, respectively; **PASS/FAIL** used proof tests-no REE, no % perm criteria

Operator Signature:

Date Signed:

Supervisor Signature:

Date Signed:

I hereby certify that all the following tests were made under my supervision and in accordance with DOT/CTC regulations.

#	Test Date Test Time	Operator	Serial Number Cyl Owner	Size Service	Cyl MFG. MFG. Date	REE Source	Rating Unit	Specified Actual	Test Time	Total Elastic	Perm Percen	++ VE	VE Date Ref Ring	Disposition Remark
16	11/8/2024 11:26	DUSTIN PHILLIPS	HP559210 TULSA GAS 2	9.25x55 Spec Gas	M9601 09/17	251 C5	3AA-2400 PSI	4000 4019	30	251.3 248.3	3.0 1.1	++		PPP
17	11/8/2024 11:35	DUSTIN PHILLIPS	HP537818 TULSA GAS 2	9.25x55 Spec Gas	M9601 08/16	278 C5	3AA-2400 PSI	4000 4015	30	253.9 252.9	1.0 0.3	++		PPP
18	11/8/2024 11:40	DUSTIN PHILLIPS	HP559200 TULSA GAS 2	9.25x55 Spec Gas	M9601 09/17	278 C5	3AA-2400 PSI	4000 4016	30	254.4 253.4	1.0 0.3	++		PPP
19	11/8/2024 11:51	DUSTIN PHILLIPS	HP559194 TULSA GAS 2	9.25x55 Spec Gas	M9601 09/17	278 C5	3AA-2400 PSI	4000 4023	30	250.1 249.1	1.0 0.4	++		PPP
20	11/8/2024 11:56	DUSTIN PHILLIPS	HP559188 TULSA GAS 2	9.25x55 Spec Gas	M9601 09/17	278 C5	3AA-2400 PSI	4000 4006	30	246.8 245.8	1.0 0.4	++		PPP
21	11/8/2024 12:05	DUSTIN PHILLIPS	HP537799 TULSA GAS 2	9.25x55 Spec Gas	M9601 08/16	278 C5	3AA-2400 PSI	4000 4016	30	249.9 245.9	4.0 1.6	++		PPP
22	11/8/2024 12:09	DUSTIN PHILLIPS	HP537802 TULSA GAS 2	9.25x55 Spec Gas	M9601 08/16	278 C5	3AA-2400 PSI	4000 4016	30	252.4 251.4	1.0 0.4	++		PPP
23	11/8/2024 12:20	DUSTIN PHILLIPS	HP537804 TULSA GAS 2	9.25x55 Spec Gas	M9601 08/16	278 C5	3AA-2400 PSI	4000 4018	30	244.4 241.4	3.0 1.2	++		PPP
24	11/8/2024 12:25	DUSTIN PHILLIPS	HP559403 TULSA GAS 2	9.25x55 Spec Gas	M9601 09/17	278 C5	3AA-2400 PSI	4000 4020	30	251.6 249.6	2.0 0.7	++		PPP
25	11/8/2024 12:33	DUSTIN PHILLIPS	HP537811 TULSA GAS 2	9.25x55 Spec Gas	M9601 08/16	278 C5	3AA-2400 PSI	4000 4012	30	251.9 250.9	1.0 0.4	++		PPP
26	11/8/2024 12:37	DUSTIN PHILLIPS	HP559192 TULSA GAS 2	9.25x55 Spec Gas	M9601 09/17	278 C5	3AA-2400 PSI	4000 4016	30	249.7 247.7	2.0 0.8	++		PPP
27	11/8/2024 12:45	DUSTIN PHILLIPS	HP537798 TULSA GAS 2	9.25x55 Spec Gas	M9601 08/16	278 C5	3AA-2400 PSI	4000 4014	30	254.2 249.2	5.0 1.9	++		PPP
28	11/8/2024 12:49	DUSTIN PHILLIPS	HP559207 TULSA GAS 2	9.25x55 Spec Gas	M9601 09/17	278 C5	3AA-2400 PSI	4000 4019	30	247.9 245.9	2.0 0.8	++		PPP
29	11/8/2024 12:57	DUSTIN PHILLIPS	HP559211 TULSA GAS 2	9.25x55 Spec Gas	M9601 09/17	278 C5	3AA-2400 PSI	4000 4019	30	251.5 248.5	3.0 1.1	++		PPP
30	11/8/2024 13:02	DUSTIN PHILLIPS	HP537800 TULSA GAS 2	9.25x55 Spec Gas	M9601 08/16	278 C5	3AA-2400 PSI	4000 4018	30	250.6 250.6	0.0 0.0	++		PPP

Test Date(s): 11/8/2024

Page 1 of 1

New Mexico Gas Recertification, 3 Trailers, 5 Bottles Each
2400 PSI Bottles As of: 03/27/25

15 Bottles for Fullerton Hydrotesting

Fullerton Pallet No. 32

Date Taken for Testing 11/5/2024

Date Certified 11/18/2024

Date Returned to TGT 11/13/2024

Date Installed on Trailers - 1/3/2025

Bottle SN#

Trailer # 18505		Driver Side
HP537804	2	
HP537818	1	
HP559194	4	
HP559210	3	
HP559403	5	

Passenger Side

Trailer # 18506		Driver Side
HP537798	1	
HP537799	2	
HP537802	5	
HP559188	3	
HP559200	4	

Passenger Side

Trailer # 18507		Driver Side
HP537800	1	
HP537811	3	
HP559192	4	
HP559207	5	
HP559211	2	

Passenger Side