

Test System: Hydrotest Machine
 Test Machine Serial#:
 License: C334

Cylinder Retest Data Sheet Hydrostatic Volumetric Test Method Report

Automatic Fire Control
 1708 S.E. 22nd Street
 Oklahoma City, OK 73129

Test ID	Cylinder Owner	Serial #	Mfr's ID	Size (D x L)	Spec/Svc Press	Visual Insp.	Test Time	Actual Press	Total Exp.	Perm. Exp.	Elastic Exp.	REE	Pct Exp.	Test Result
1	ONG	1201108Y	NORRIS	9 X 51	3AA3600	Pass	30	6000 PSI	209.6	1.4	208.2	0.0	0.7	Pass
	01/09/2025 10:32	5	JD	A: Return to service	Notes:									
3	ONG	1201096Y	NORRIS	9 X 51	3AA3600	Pass	30	6000 PSI	205.7	1.8	203.9	0.0	0.9	Pass
	01/09/2025 10:33	5	JD	A: Return to service	Notes:									
4	ONG	1429390Y	NORRIS	9 X 51	3AA3600	Pass	30	6000 PSI	200.2	0.5	199.7	0.0	0.2	Pass
	01/09/2025 10:33	5	JD	A: Return to service	Notes:									
5	ONG	1418925Y	NORRIS	9 X 51	3AA3600	Pass	30	6000 PSI	207.5	1.9	205.6	0.0	0.9	Pass
	01/09/2025 10:33	5	JD	A: Return to service	Notes:									
6	ONG	1429397Y	NORRIS	9 X 51	3AA3600	Pass	30	6000 PSI	199.5	1.0	198.5	0.0	0.5	Pass
	01/09/2025 10:33	5	JD	A: Return to service	Notes:									
7	ONG	1201077Y	NORRIS	9 X 51	3AA3600	Pass	30	6000 PSI	208.6	1.7	206.9	0.0	0.8	Pass
	01/09/2025 10:33	5	JD	A: Return to service	Notes:									
8	ONG	1418927Y	NORRIS	9 X 51	3AA3600	Pass	30	6000 PSI	200.8	1.6	199.2	0.0	0.8	Pass
	01/09/2025 10:33	5	JD	A: Return to service	Notes:									
9	ONG	1429381Y	NORRIS	9 X 51	3AA3600	Pass	30	6000 PSI	201.4	1.0	200.4	0.0	0.5	Pass
	01/09/2025 10:34	5	JD	A: Return to service	Notes:									
10	ONG	1429407Y	NORRIS	9 X 51	3AA3600	Pass	30	6000 PSI	202.8	1.4	201.4	0.0	0.7	Pass
	01/09/2025 10:34	5	JD	A: Return to service	Notes:									
11	ONG	1429382Y	NORRIS	9 X 51	3AA3600	Pass	30	6000 PSI	207.9	2.3	205.6	0.0	1.1	Pass
	01/09/2025 10:34	5	JD	A: Return to service	Notes:									
12	ONG	1418941Y	NORRIS	9 X 51	3AA3600	Pass	30	6000 PSI	202.5	1.7	200.8	0.0	0.8	Pass
	01/09/2025 10:34	5	JD	A: Return to service	Notes:									
13	ONG	1429387Y	NORRIS	9 X 51	3AA3600	Pass	30	6000 PSI	200.7	1.3	199.4	0.0	0.6	Pass
	01/09/2025 10:34	5	JD	A: Return to service	Notes:									
14	ONG	1418971Y	NORRIS	9 X 51	3AA3600	Pass	30	6000 PSI	200.5	1.7	198.8	0.0	0.8	Pass
	01/09/2025 10:34	5	JD	A: Return to service	Notes:									

Test System: Hydrotest Machine
 Test Machine Serial#:
 License: C334

Cylinder Retest Data Sheet Hydrostatic Volumetric Test Method Report

Automatic Fire Control
 1708 S.E. 22nd Street
 Oklahoma City, OK 73129

Test ID	Cylinder Owner	Serial #	Mfgr's ID	Size (D x L)	Spec/Svc Press	Visual Insp.	Test Time	Actual Press	Total Exp.	Perm. Exp.	Elastic Exp.	REE	Pct Exp.	Test Result
1	ONG	1252734Y	NORRIS	9 X 51	3AA3600	Pass	30	6000 PSI	209.4	1.6	207.8	0.0	0.8	Pass
	01/09/2025 10:37	5	JD	A: Return to service	Notes:									
2	ONG - Kept	MDF 10026	NORRIS	9 X 51	3AA3600	Pass	30	6000 PSI	206.5	2.3	204.2	0.0	1.1	Pass
	01/09/2025 10:37	5	JD	A: Return to service	Notes:									
3	ONG	10012	NORRIS	9 X 51	3AA3600	Pass	30	6000 PSI	209.1	1.5	207.6	0.0	0.7	Pass
	01/09/2025 10:37	5	JD	A: Return to service	Notes:									
4	ONG	10043	NORRIS	9 X 51	3AA3600	Pass	30	6000 PSI	204.1	0.6	203.5	0.0	0.3	Pass
	01/09/2025 10:37	5	JD	A: Return to service	Notes:									
5	ONG	10034	NORRIS	9 X 51	3AA3600	Pass	30	6000 PSI	210.1	1.9	208.2	0.0	0.9	Pass
	01/09/2025 10:37	5	JD	A: Return to service	Notes:									
6	ONG	1252754Y	NORRIS	9 X 51	3AA3600	Pass	30	6000 PSI	212.1	1.2	210.9	0.0	0.6	Pass
	01/09/2025 10:38	5	JD	A: Return to service	Notes:									
7	ONG	10057	NORRIS	9 X 51	3AA3600	Pass	30	6000 PSI	212.2	2.1	210.1	0.0	1.0	Pass
	01/09/2025 10:38	5	JD	A: Return to service	Notes:									
8	ONG	10030	NORRIS	9 X 51	3AA3600	Pass	30	6000 PSI	211.8	1.0	210.8	0.0	0.5	Pass
	01/09/2025 10:38	5	JD	A: Return to service	Notes:									
9	ONG	10041	NORRIS	9 X 51	3AA3600	Pass	30	6000 PSI	207.4	1.6	205.8	0.0	0.8	Pass
	01/09/2025 10:38	5	JD	A: Return to service	Notes:									

1/17/25 - Roy of ONG delivered 28 Bottles to TGT Today -
 He kept bottle #2 - Serial # MDF 10026

EM

Test System: Hydrotest Machine
 Test Machine Serial#:
 License: C334

Cylinder Retest Data Sheet

Hydrostatic Volumetric Test Method Report

Automatic Fire Control
 1708 S.E. 22nd Street
 Oklahoma City, OK 73129

Test ID	Cylinder Owner	Serial #	Mfg'r's ID	Size (D x L)	Spec/Svc Press	Visual Insp.	Test Time	Actual Press	Total Exp.	Perm. Exp.	Elastic Exp.	REE	Pct Exp.	Test Result
1	ONG	1418962Y	NORRIS	9 X 51	3AA3600	Pass	30	6000 PSI	201.9	1.8	200.1	0.0	0.9	Pass
	01/13/2025 14:55	5	JD	A: Return to service	Notes:									
2	ONG	1429386Y	NORRIS	9 X 51	3AA3600	Pass	30	6000 PSI	203.4	1.3	202.1	0.0	0.6	Pass
	01/13/2025 14:55	5	JD	A: Return to service	Notes:									
3	ONG	1429389Y	NORRIS	9 X 51	3AA3600	Pass	30	6000 PSI	199.4	1.6	197.8	0.0	0.8	Pass
	01/13/2025 14:56	5	JD	A: Return to service	Notes:									
4	ONG	1429383Y	NORRIS	9 X 51	3AA3600	Pass	30	6000 PSI	209.6	0.3	209.3	0.0	0.1	Pass
	01/13/2025 14:56	5	JD	A: Return to service	Notes:									
5	ONG	1429392Y	NORRIS	9 X 51	3AA3600	Pass	30	6000 PSI	202.8	1.7	201.1	0.0	0.8	Pass
	01/13/2025 14:56	5	JD	A: Return to service	Notes:									
6	ONG	1418926Y	NORRIS	9 X 51	3AA3600	Pass	30	6000 PSI	208.6	1.4	207.2	0.0	0.7	Pass
	01/13/2025 14:56	5	JD	A: Return to service	Notes:									
7	ONG	1429385Y	NORRIS	9 X 51	3AA3600	Pass	30	6000 PSI	201.2	1.9	199.3	0.0	0.9	Pass
	01/13/2025 14:57	5	JD	A: Return to service	Notes:									