

**7441 – A & B**





HYDROSTATIC TEST REPORT

DATE: 20 NOV. '22

Job Number: 7441-B

Customer: LOVAT

Description of Product: HEATER PIPING

Tests Conducted By: PPL

Test Pressure: 9275, 5575, 450 PSIG

Holding Time at Test Pressure: ONE HOUR

Results: GOOD

Authorized Inspector Witnessing Tests: \_\_\_\_\_

Comments: \_\_\_\_\_

Temperature: 60° F AMBIANT

Gauge #1: SW130604-7

Gauge #2: PPL 3.2

Gauge #3 PPL A

  
\_\_\_\_\_  
Signature of Quality Control Manager

**7441 – A & B**







HYDROSTATIC TEST REPORT

DATE: 20 NOV. '22

Job Number: 7441-B

Customer: LOVAT

Description of Product: HEATER PIPING

Tests Conducted By: PPL

Test Pressure: 9275, 5575, 450 PSIG

Holding Time at Test Pressure: ONE HOUR

Results: GOOD

Authorized Inspector Witnessing Tests: \_\_\_\_\_

Comments: \_\_\_\_\_

Temperature: 60° F AMBIANT

Gauge #1: SW130604-7

Gauge #2: PPL 3.2

Gauge #3: PPL A

  
\_\_\_\_\_  
Signature of Quality Control Manager



HYDROSTATIC TEST REPORT

DATE: 17 NOV. '22

Job Number: 7441-A

Customer: LOVAT

Description of Product: HEATER PIPING

Tests Conducted By: PPL

Test Pressure: 9275, 5575, 450 PSIG

Holding Time at Test Pressure: ONE HOUR

Results: GOOD

Authorized Inspector Witnessing Tests: \_\_\_\_\_

Comments: \_\_\_\_\_

Temperature: 60° F AMBIANT

Gauge #1: SW130604-7

Gauge #2: PPL 3.2

Gauge #3 PPL A

  
\_\_\_\_\_  
Signature of Quality Control Manager



# GAUGE CALIBRATION FORM

<b>CLIENT NAME:</b>	Priority Projects	<b>WORK ORDER #:</b>	WO 22-1071
<b>LOCATION:</b>			

<b>DEVICE TAG:</b>	JW130604-7	<b>SERVICE:</b>	Calibration
<b>MANUFACTURER:</b>	Wika	<b>MODEL NO.:</b>	4" Face 1/2" NPT
<b>SERIAL NO.:</b>	JW130604-7	<b>DESCRIPTION:</b>	

<b>INSTRUMENT RANGE:</b>	0 - 15 000 PSI	<b>CALIBRATION RANGE:</b>	0 - 15 000 PSI
<b>OUTPUT RANGE:</b>	0 - 15 000 PSI	<b>INDICATOR RANGE:</b>	0 - 15 000 PSI

% INPUT	INPUT	AS FOUND	AS LEFT
0	0 PSI	0 PSI	0 PSI
25	3750 PSI	3750 PSI	3750 PSI
50	7500 PSI	7500 PSI	7500 PSI
75	11 250 PSI	11 250 PSI	11 250 PSI
100	15 000 PSI	15 000 PSI	15 000 PSI
75	11 250 PSI	11 250 PSI	11 250 PSI
50	7500 PSI	7500 PSI	7500 PSI
25	3750 PSI	3750 PSI	3750 PSI
0	0 PSI	0 PSI	0 PSI

### CALIBRATION EQUIPMENT

<b>MANUFACTURER:</b>	Crystal	<b>MODEL NO.:</b>	NVISION	<b>TYPE:</b>	Deadweight
<b>SERIAL NO.:</b>	705085 (FC-106)	<b>TEST RANGE:</b>	0 - 15 000 PSI	<b>CALIBRATION DATE:</b>	15-Nov-2021
<b>MANUFACTURER:</b>		<b>MODEL NO.:</b>		<b>TYPE:</b>	
<b>SERIAL NO.:</b>		<b>TEST RANGE:</b>		<b>CALIBRATION DATE:</b>	

### NOTES:

Passed Calibration. No problems.  
 COMMENTS: The instrument was calibrated against laboratory standards that are either traceable to the National Institute of Standards and Technology, (NIST), National Research Council, (NRC), or are derived by approved ratio techniques. Gauge has been tested within 2% of full scale reading.

**RECALIBRATION DUE DATE:** 27-Sep-2023

<b>VERIFIED BY:</b>	Chris Kurtz	<b>SIGN:</b>		<b>CALIBRATION DATE:</b>	27-Sep-2022
---------------------	-------------	--------------	---	--------------------------	-------------

<b>CLIENT NAME:</b>	Priority Projects	<b>WORK ORDER #:</b>	WO 22-1071
<b>LOCATION:</b>			

<b>DEVICE TAG:</b>	PPL 3.2	<b>SERVICE:</b>	Calibration
<b>MANUFACTURER:</b>	Wika	<b>MODEL NO.:</b>	2" Face 1/4" NPT
<b>SERIAL NO.:</b>	PPL 3.2	<b>DESCRIPTION:</b>	

<b>INSTRUMENT RANGE:</b>	0 - 10 000 PSI	<b>CALIBRATION RANGE:</b>	0 - 10 000 PSI
<b>OUTPUT RANGE:</b>	0 - 10 000 PSI	<b>INDICATOR RANGE:</b>	0 - 10 000 PSI


% INPUT	INPUT	AS FOUND	AS LEFT
0	0 PSI	0 PSI	0 PSI
25	2500 PSI	2500 PSI	2500 PSI
50	5000 PSI	5000 PSI	5000 PSI
75	7500 PSI	7500 PSI	7500 PSI
100	10 000 PSI	10 000 PSI	10 000 PSI
75	7500 PSI	7500 PSI	7500 PSI
50	5000 PSI	5000 PSI	5000 PSI
25	2500 PSI	2500 PSI	2500 PSI
0	0 PSI	0 PSI	0 PSI

### CALIBRATION EQUIPMENT

<b>MANUFACTURER:</b>	Crystal	<b>MODEL NO.:</b>	XP2I	<b>TYPE:</b>	Deadweight
<b>SERIAL NO.:</b>	561813 (FC-107)	<b>TEST RANGE:</b>	0 - 10 000 PSI	<b>CALIBRATION DATE:</b>	15-Nov-2021
<b>MANUFACTURER:</b>		<b>MODEL NO.:</b>		<b>TYPE:</b>	
<b>SERIAL NO.:</b>		<b>TEST RANGE:</b>		<b>CALIBRATION DATE:</b>	

### NOTES

Passed Calibration. No problems.  
**COMMENTS:** The instrument was calibrated against laboratory standards that are either traceable to the National Institute of Standards and Technology, (NIST), National Research Council, (NRC), or are derived by approved ratio techniques. Gauge has been tested within 2% of full scale reading.

			<b>RECALIBRATION DUE DATE:</b>	27-Sep-2023	
<b>VERIFIED BY:</b>	Chris Kutz	<b>SIGN:</b>		<b>CALIBRATION DATE:</b>	27-Sep-2022

<b>CLIENT NAME:</b>	Priority Projects	<b>WORK ORDER #:</b>	WO 22-1071
<b>LOCATION:</b>			

<b>DEVICE TAG:</b>	PPL A	<b>SERVICE:</b>	Calibration
<b>MANUFACTURER:</b>	McDaniel	<b>MODEL NO.:</b>	2" Face 1/4" NPT
<b>SERIAL NO.:</b>	PPL A	<b>DESCRIPTION:</b>	

<b>INSTRUMENT RANGE:</b>	0 - 1000 PSI	<b>CALIBRATION RANGE:</b>	0 - 1000 PSI
<b>OUTPUT RANGE:</b>	0 - 1000 PSI	<b>INDICATOR RANGE:</b>	0 - 1000 PSI

% INPUT	INPUT	AS FOUND	AS LEFT
0	0 PSI	0 PSI	0 PSI
25	250 PSI	250 PSI	250 PSI
50	500 PSI	500 PSI	500 PSI
75	750 PSI	750 PSI	750 PSI
100	1000 PSI	1000 PSI	1000 PSI
75	750 PSI	750 PSI	750 PSI
50	500 PSI	500 PSI	500 PSI
25	250 PSI	250 PSI	250 PSI
0	0 PSI	0 PSI	0 PSI


### CALIBRATION EQUIPMENT

<b>MANUFACTURER:</b>	Crystal	<b>MODEL NO.:</b>	XP21	<b>TYPE:</b>	Deadweight
<b>SERIAL NO.:</b>	561813 (FC-107)	<b>TEST RANGE:</b>	0 - 10 000 PSI	<b>CALIBRATION DATE:</b>	15-Nov-2021
<b>MANUFACTURER:</b>		<b>MODEL NO.:</b>		<b>TYPE:</b>	
<b>SERIAL NO.:</b>		<b>TEST RANGE:</b>		<b>CALIBRATION DATE:</b>	

### NOTES:

Passed Calibration. No problems.

COMMENTS: The instrument was calibrated against laboratory standards that are either traceable to the National Institute of Standards and Technology, (NIST), National Research Council, (NRC), or are derived by approved ratio techniques. Gauge has been tested within 2% of full scale reading.

			<b>RECALIBRATION DUE DATE:</b>	27-Sep-2023	
<b>VERIFIED BY:</b>	Chris Kutz	<b>SIGN:</b>		<b>CALIBRATION DATE:</b>	27-Sep-2022