

# HOSE 1

Prover Starting Mass	0.0000					
Prover 1st Batch	12.4000					
Dispenser 1st Batch	12.340	0.48 %				
Prover 2nd Batch	24.8900					
Dispenser 2nd Batch	12.460	0.24 %				
Prover 3rd Batch	35.3200					
Dispenser 3rd Batch	10.240	1.82 %				
Prover 4th Batch	0.000					
Dispenser 4th Batch	0.000	100.00 %				
STARTING PROVER READING						
Lb/GGE	0.0000	SCALE	SCALE/GGE	GALLONS	PERCENT of ERROR	NEW GGE FACTOR
1	12.4000	12.4000	12.400	12.340	0.48	1.01
	24.8900	12.4900	12.490	12.460	0.24	
	35.3200	10.4300	10.430	10.240	1.82	
						<b>0.85%</b>

# HOSE 2

Prover Starting Mass	0.0000					
Prover 1st Batch	12.4000					
Dispenser 1st Batch	12.380	0.16 %				
Prover 2nd Batch	23.6800					
Dispenser 2nd Batch	11.220	0.53 %				
Prover 3rd Batch	36.5800					
Dispenser 3rd Batch	12.950	-0.39 %				
Prover 4th Batch						
Dispenser 4th Batch		100.00 %				
STARTING PROVER READING						
Lb/GGE	0.0000	SCALE	SCALE/GGE	GALLONS	PERCENT of ERROR	NEW GGE FACTOR
1	12.4000	12.4000	12.400	12.380	0.16	1.00
	23.6800	11.2800	11.280	11.220	0.53	
	36.5800	12.9000	12.900	12.950	-0.39	
						<b>0.10%</b>