

# Tulsa Gas Technologies, Inc.

# Calibration Report

4809 South 101st East Ave.  
Tulsa, OK 74146  
Phone 918-665-2641 Fax 918-665-2657

**DATE:** February 20, 2019  
**Test #**  
**Test Date:** 2/20/2019  
**Tested By:** Josh Breedlove/Dylan Higginbotham  
**Test Type:** Acceptance

**Test Site:**  
Tulsa Gas Technologies, Inc.  
4809 South 101st East Ave.  
Tulsa, OK 74146

**CONTACT:** Jerry Kelley  
**PHONE:** 918 665 2641

**Work Order Number:**  
TRIL120517

**Customer Name:**  
Tulsa Gas Technologies  
4809 South 101st East Ave.  
Tulsa, OK. 74146

**Dispenser Model Number:**  
T-7214-12-8CNG50

**Dispenser Serial Number:**  
18011205

**Eprom Number:**  
1.07.02

	SCALE	DISPENSER	PERCENT of ERROR
<b>HOSE 1</b>	<b>MASS/GGE</b>	<b>GGE</b>	
	9.62	9.590	0.31%
	10.23	10.260	-0.29%
	9.50	9.460	0.42%
<b>HOSE 2</b>	9.81	9.790	0.20%
	10.44	10.480	-0.38%
	9.68	9.650	0.31%

EXPECTABLE TOLERANCE IS + - 2% FOR EACH BATCH  
AND + - .8% BETWEEN BATCHES PER EACH HOSE