

Tulsa Gas Technologies, Inc.

Calibration Report

4809 South 101st East Ave.
Tulsa, OK 74146
Phone 918-665-2641 Fax 918-665-2657

DATE: October 9, 2017

Test #

Test Date: 10/9/2017

Tested By: Dylan Higginbotham/J.T. Breedlove

Test Type Acceptance

Test Site:

Tulsa Gas Technologies, Inc.
4809 South 101st East Ave.
Tulsa, OK 74146

CONTACT: Jerry Kelley

PHONE: 918 665 2641

Work Order Number:

Trillium-PennDOT-Allentown

Customer Name:

Tulsa Gas Technologies
4809 South 101st East Ave.
Tulsa, OK. 74146

Dispenser Model Number:

T-7204-12CNG50W

Dispenser Serial Number:

17071181

Eprom Number:

1.04.21

	SCALE	DISPENSER	PERCENT of ERROR
HOSE 1	MASS/GGE	GGE	
	10.22	10.270	-0.49%
	11.07	11.110	-0.36%
	11.41	11.480	-0.61%
HOSE 2	10.87	10.890	-0.18%
	9.87	9.870	0.00%
	11.48	11.480	0.00%

EXPECTABLE TOLERANCE IS + - 2% FOR EACH BATCH
AND + - .8% BETWEEN BATCHES PER EACH HOSE