

Tulsa Gas Technologies, Inc.

Calibration Report

4809 South 101st East Ave.
Tulsa, OK 74146
Phone 918-665-2641 Fax 918-665-2657

DATE: October 9, 2017
Test #
Test Date: 10/9/2017
Tested By: Dylan Higginbotham/J.T. Breedlove
Test Type Acceptance

Test Site:
Tulsa Gas Technologies, Inc.
4809 South 101st East Ave.
Tulsa, OK 74146

CONTACT: Jerry Kelley
PHONE: 918 665 2641

Work Order Number:
Trillium-PennDOT-Allentown

Customer Name:
Tulsa Gas Technologies
4809 South 101st East Ave.
Tulsa, OK. 74146

Dispenser Model Number:
T-7104-12CNG50W

Dispenser Serial Number:
17071182

Eprom Number:
1.04.21

	SCALE	DISPENSER	PERCENT of ERROR
HOSE 1	MASS/GGE	GGE	
	1.00	1.000	0.00%
	1.00	1.000	0.00%
	1.00	1.000	0.00%
HOSE 2	10.75	10.760	-0.09%
	11.72	11.740	-0.17%
	11.61	11.630	-0.17%

EXPECTABLE TOLERANCE IS + - 2% FOR EACH BATCH
AND + - .8% BETWEEN BATCHES PER EACH HOSE