

# Tulsa Gas Technologies, Inc.

# Calibration Report

4809 South 101st East Ave.  
Tulsa, OK 74146  
Phone 918-665-2641 Fax 918-665-2657

**DATE:** December 28, 2016

**Test #**

**Test Date:** 12/28/2016

**Tested By:** Dylan Higginbotham/J.T. Breedlove

**Test Type** Acceptance

**Test Site:**

Tulsa Gas Technologies, Inc.  
4809 South 101st East Ave.  
Tulsa, OK 74146

**CONTACT:** Jerry Kelley

**PHONE:** 918 665 2641

**Work Order Number:**

TRIL01416A

**Customer Name:**

Tulsa Gas Technologies  
4809 South 101st East Ave.  
Tulsa, OK. 74146

**Dispenser Model Number:**

T7104-12CNG50W

**Dispenser Serial Number:**

16121140

**Eprom Number:**

1.04.70

	SCALE	DISPENSER	PERCENT of ERROR
HOSE 1	MASS/GGE	GGE	
	0.00	0.000	#DIV/0!
	0.00	0.000	#DIV/0!
	0.00	0.000	#DIV/0!
HOSE 2	32.45	32.512	-0.20%
	29.71	29.754	-0.14%
	29.64	29.684	-0.15%

EXPECTABLE TOLERANCE IS + - 2% FOR EACH BATCH  
AND + - .8% BETWEEN BATCHES PER EACH HOSE

