

Tulsa Gas Technologies, Inc.

4809 South 101st East Ave.
Tulsa, OK 74146
Phone 918-665-2641 Fax 918-665-2657

Calibration Report

DATE: December 28, 2016

Test #

Test Date: 12/28/2016

Tested By: Dylan Higginbotham/J.T. Breedlove

Test Type: Acceptance

Test Site:

Tulsa Gas Technologies, Inc.
4809 South 101st East Ave.
Tulsa, OK 74146

CONTACT: Jerry Kelley

PHONE: 918 665 2641

Work Order Number:

TRIL01416A

Customer Name:

Tulsa Gas Technologies
4809 South 101st East Ave.
Tulsa, OK. 74146

Dispenser Model Number:

T7104-12CNG50W

Dispenser Serial Number:

16121144

Eprom Number:

1.04.70

	SCALE	DISPENSER	PERCENT of ERROR
HOSE 1	MASS/GGE	GGE	
	0.00	0.000	#DIV/0!
	0.00	0.000	#DIV/0!
	0.00	0.000	#DIV/0!
HOSE 2	5.97	5.996	-0.52%
	7.11	7.132	-0.27%
	6.16	6.182	-0.31%

EXPECTABLE TOLERANCE IS + - 2% FOR EACH BATCH
AND + - .8% BETWEEN BATCHES PER EACH HOSE

