

Tulsa Gas Technologies, Inc.

4809 South 101st East Ave.
Tulsa, OK 74146
Phone 918-665-2641 Fax 918-665-2657

Calibration Report

DATE: December 28, 2016

Test #

Test Date: 12/28/2016

Tested By: Dylan Higginbotham/J.T. Breedlove

Test Type Acceptance

Test Site:

Tulsa Gas Technologies, Inc.
4809 South 101st East Ave.
Tulsa, OK 74146

CONTACT: Jerry Kelley

PHONE: 918 665 2641

Work Order Number:

TRIL01416A

Customer Name:

Tulsa Gas Technologies
4809 South 101st East Ave.
Tulsa, OK. 74146

Dispenser Model Number:

T7214-12CNG50W

Dispenser Serial Number:

16121148

Eprom Number:

1.04.61

	SCALE	DISPENSER	PERCENT of ERROR
HOSE 1	MASS/GGE	GGE	
	6.18	6.180	0.05%
	6.50	6.492	0.05%
	6.57	6.564	0.06%
HOSE 2	6.18	6.164	0.21%
	6.00	5.998	0.02%
	6.06	6.060	-0.07%

EXPECTABLE TOLERANCE IS + - 2% FOR EACH BATCH
AND + - .8% BETWEEN BATCHES PER EACH HOSE

HOSE 1

Prover Starting Mass	0.0000					
Prover 1st Batch	6.1830					
Dispenser 1st Batch	6.180	0.05 %				
Prover 2nd Batch	12.6780					
Dispenser 2nd Batch	6.492	0.05 %				
Prover 3rd Batch	19.2460					
Dispenser 3rd Batch	6.564	0.06 %				
Prover 4th Batch	133.001					
Dispenser 4th Batch	113.364	0.34 %				

STARTING PROVER READING

Lb/GGE	SCALE	SCALE/GGE	GALLONS	PERCENT of ERROR	NEW GGE FACTOR
1	6.1830	6.1830	6.183	6.180	0.05
	12.6780	6.4950	6.495	6.492	0.05
	19.2460	6.5680	6.568	6.564	0.06

0.05%

HOSE 2

Prover Starting Mass	0.0000				
Prover 1st Batch	6.1770				
Dispenser 1st Batch	6.164	0.21 %			
Prover 2nd Batch	12.1760				
Dispenser 2nd Batch	5.998	0.02 %			
Prover 3rd Batch	18.2320				
Dispenser 3rd Batch	6.060	-0.07 %			
Prover 4th Batch					
Dispenser 4th Batch		100.00 %			

STARTING PROVER READING

Lb/GGE	SCALE	SCALE/GGE	GALLONS	PERCENT of ERROR	NEW GGE FACTOR
1	6.1770	6.1770	6.177	6.164	0.21
	12.1760	5.9990	5.999	5.998	0.02
	18.2320	6.0560	6.056	6.060	-0.07

0.05%